Base Load Power Hub (BLPH)

INSTRUMENT AIR PACKAGE A-63000
INSTRUMENT DATA SHEETS

Document Number: 1724000428-MAC-DS-00013

ROSETTI MARINO

1	NO COMMENTS - APPROVED - WORK MAY PROCEED
2	MINOR COMMENTS - REVISE AND RESUBMIT - WORK MAY PROCEED
3	MAJOR COMMENTS – REJECTED – DO NOT PROCEED
4	APPROVAL NOT REQUIRED

NOTE: Approval doesn't relieve the supplier from mandatory compliance with contractual documents and specifications. Comments made do not imply acceptance of any cost or delivery impact.

Sign	Date
Giuseppe Cavallo	25/01/25

Document Class: 3

Rev.	Date	Description	Prepared	Reviewed	Approved
03	02/01/2025	Issue for Information (IFI)	GT	MC	TM
02	04/09/2024	Issue for Information (IFI)	GT	MC	TM
01	01/07/2024	Issue for Information (IFI)	GT	MC	TM
00	02/05/2024	Issue for Information (IFI)	GT	MC	TM

COES

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Revision / Change Log

Rev.	Description
00	Issue for Information (IFI)
01	Issue for Information (IFI)
02	Issue for Information (IFI)
03	Issue for Information (IFI)

HOLDS LIST

No.	Description
1	
2	
3	
4	

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Table of contents

1 INTRODUCTION 5

1.1 PROJECT OVERVIEW 5

1.1.1 Project Location 5

1.1.2 Project Concept 6

2 DOCUMENT SCOPE 8

2.1 REFERENCES 8

2.2 DEFINITIONS AND ABBREVIATIONS 8

3 INSTRUMENT DATASHEETS 9

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

List of Figures

Figure 1 HOLLANDSE KUST NOORD WIND PARK Location Map 5

Figure 2 - Wind Park Details 6

Figure 3 – BLPH Concept 6

List of tables

Table 1 - Reference Documents 8

Table 2 - Definitions and Abbreviations 8

List of Attachments

None

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

1 INTRODUCTION

1.1 PROJECT OVERVIEW

Crosswind, a Shell and Eneco joint venture, was awarded the tender to develop the offshore Hollandse Kust Noord (HKN) wind farm, located 18.5km off the coast of Netherlands near the town of Egmond aan Zee. The consortium plans to have HKN operational in 2023 with an installed capacity of 759MW generating at least 3.3TWh per year. This is sufficient renewable power to supply more than 1 million Dutch households with green electricity.

Offshore wind farms produce intermittent electricity and balancing these dips and peaks and integrating this electricity into the national energy system requires new technologies. For this reason, the offshore wind farm will include several new technologies that could be implemented at full-scale in the future. The new technologies being explored include a floating solar park, a short-duration battery storage as well as long-term storage via green hydrogen produced by water electrolysis and subsequently consumed in a fuel cell. The combination of these individual measures, herein referred to as the Base Load Power Hub (BLPH) will ensure a continuous power supply regardless of the wind situation.

1.1.1 Project Location

The Hollandse Kust Noord (HKN) wind farm is located 18.5km off the coast of the Netherlands near the town of Egmond aan Zee.




Figure 1 HOLLANDSE KUST NOORD WIND PARK Location Map



Figure 2 - Wind Park Details

The wind farm will consist of No. 69 x 11.5MW wind turbine generators each to be installed on a dedicated monopile structure. A 70th monopile located on coordinates E 590719.1, N 5841602.3 is reserved for installing the platform accommodating the BLPH. The monopile structure was designed and installed by Van Oord Offshore Wind (VooW) and therefore not part of the BLPH scope.

1.1.2 Project Concept

All components included in the BLPH will be integrated onshore on a topsides and installed in an offshore location within the boundaries of the HKN wind farm. At its simplest, the BLPH will store energy during periods of high electricity generation from renewable sources (a wind turbine generator and the floating solar PV farm) and release it during periods of low generation. In practice. It is expected that the energy stored will supplement generation from renewable sources to ensure that at least 1.0MW of power is exported to the electrical grid regardless of wind/solar availability.




Figure 3 – BLPH Concept

Electricity in the BLPH will be stored in the form of electrons in a battery energy storage system (BESS) as well as converted into green hydrogen via water electrolysis. When the power output from the connecting wind turbine drops to below 1 MWe, the BLPH will return its stored energy to supplement the remaining power output. This will be by discharging the BESS, while stored hydrogen will be converted back into electricity using a fuel cell to extend the discharge duration.

The purpose of the BLPH s to function as a testbed for the integration of energy storage technologies with renewable generation. It is expected that equipment installed on the BLPH will operate as Normally Unmanned Installation for at least two (2) years with no or minimal maintenance and it will have its own independent control room with the ability to communicate with Crosswind's control room.

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

2 DOCUMENT SCOPE

This document identifies any electrical equipment to be fed with its main characteristics.

2.1 REFERENCES

Doc. No.	Description
1724000428-PR-PID-00019	PACKAGE P&ID
1724000428-MAC-DS-00011	EQUIPMENT DATA SHEETS INCLUDING MOTORS, AIR COMPRESSOR, DRYERS, ETC.

Table 1 - Reference Documents

2.2 DEFINITIONS AND ABBREVIATIONS

COMPANY or Client (CPY):	Crosswind
CONTRACTOR (CTR):	ROSETTI MARINO S.p.A.
PROJECT:	HOLLANDSE KUST NOORD WIND PARK Project
RF	RAISED FACE

Table 2 - Definitions and Abbreviations

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

3 INSTRUMENT DATASHEETS

PRESSURE TRANSMITTER			
General	1	Tag number	63-PIT-064
	2	Service	Instrument air receiver pressure
	3	Quantity	1
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Transmitter	11	Output	4…20mA HART 7
	12	Available range	-0.98 ÷ 20.7 bar
	13	Calibrated range	0 ÷ 16 barg
	14	Element type	Isolating Diaphragm
	15	Wetted parts material	SS 316L
	16	Element material	SS 316L
	17	Case material	SS 316L
	18	Execution	IP66
	19	Process connections	Female thread 1/2-14 NPT-F
	20	Cable entry	M20x1.5
	21	Digital display	YES - LCD type integrated
	22	Accuracy	Better than 0,25% of adjusted span
	23	Power supply	24 VDC
	24	Certification:	ATEX, II 1/2 G Ex db IIC T6…T4 Ga/Gb
Accessories	25	Manifold Supplier	EMERSON
	26	Manifold type / Model	2-Valves / R305C22B11L4
	27	Manifold mat.l Body / seal	SS316 / PTFE
Purchase	28	Instrument Manufacturer	EMERSON
	29	Model	2051CG4A22A1KS5E8L4M5D4T1Q4Q8HR7
Notes	30		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

DIFFERENTIAL PRESSURE TRANSMITTER			
General	1	Tag number	63-PDIT-051, 63-PDIT-062
	2	Service	Pre-filters, After-filters pressure drop
	3	Quantity	1 + 1
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Transmitter	11	Output	4…20mA HART 7
	12	Available range	-2.5 ÷ 2.5 bar
	13	Calibrated range	0 ÷ 1 bar
	14	Element type	Isolating Diaphragm
	15	Wetted parts material	SS 316L
	16	Element material	SS 316L
	17	Case material	SS 316L
	18	Execution	IP66
	19	Process connections	Female thread 1/2-14 NPT-F
	20	Cable entry	M20x1.5
	21	Digital display	YES - LCD type integrated
	22	Accuracy	Better than 0,25% of adjusted span
	23	Power supply	24 VDC
	24	Certification:	ATEX, II 1/2 G Ex db IIC T6…T4 Ga/Gb
Accessories	25	Manifold Supplier	EMERSON
	26	Manifold type / Model	5-Valves / R305RC52B11
	27	Manifold mat.l Body / seal	SS316 / PTFE
Purchase	28	Instrument Manufacturer	EMERSON
	29	Model	2051CD3A22A1KS5E8L4M5D4T1Q4Q8HR7
Notes	30		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

PRESSURE GAUGES			
General	1	Tag number	63-PI-053, 63-PI-055, 63-PI-057, 63-PI-059
	2	Service	Dryer towers pressure
	3	Quantity	4
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Gauge	11	Type	Bourdon Tube
	12	Range	0 ÷ 16 barg
	13	Mounting	Local
	14	Dial size	DN100 mm
	15	Dial / Pointer color / material	White / black / aluminum
	16	Case material	Stainless steel SS 316
	17	Ring material	Stainless steel SS 316
	18	Blow out protection	With solid baffle wall and blow-out back
	19	Lens material	Safety glass
	20	Pressure element type	Bourdon
	21	Pressure element material	SS 316L (1.4571)
	22	Socket material	Stainless Steel SS 316
	23	Movement material	Stainless Steel SS 316
	24	Connection size	1/2" NPT-M
	25	Connection type	Radial Bottom
	26	Protection degree	IP66
	27	Nominal accuracy	CLASS 1 EN837 - 1% on range
	28	Over pressure	30% of span
	29	Certification:	ATEX, Ex h Gas II 2G Ex h IIC T6 ...T1 Gb X
Accessories	30	Diaphragm seal	NO
	31	Manifold type	2 Valves
Purchase	32	Instruments Manufacturer	WIKA
	33	Model	233.30
Notes	34		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

PRESSURE GAUGES			
General	1	Tag number	63-PI-063
	2	Service	Air receiver pressure
	3	Quantity	1
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Gauge	11	Type	Bourdon Tube
	12	Range	0 ÷ 16 barg
	13	Mounting	Local
	14	Dial size	DN100 mm
	15	Dial / Pointer color / material	White / black / aluminum
	16	Case material	Stainless steel SS 316
	17	Ring material	Stainless steel SS 316
	18	Blow out protection	With solid baffle wall and blow-out back
	19	Lens material	Safety glass
	20	Pressure element type	Bourdon
	21	Pressure element material	SS 316L (1.4571)
	22	Socket material	Stainless Steel SS 316
	23	Movement material	Stainless Steel SS 316
	24	Connection size	1/2" NPT-M
	25	Connection type	Radial Bottom
	26	Protection degree	IP66
	27	Nominal accuracy	CLASS 1 EN837 - 1% on range
	28	Over pressure	30% of span
	29	Certification:	ATEX, Ex h Gas II 2G Ex h IIC T6 ...T1 Gb X
Accessories	30	Diaphragm seal	NO
	31	Manifold type	2 Valves
Purchase	32	Instruments Manufacturer	WIKA
	33	Model	233.30
Notes	34		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

DIFFERENTIAL PRESSURE GAUGES			
General	1	Tag number	63-PDI-052, 63-PDI-061
	2	Service	Dryer pressure drop
	3	Quantity	1 + 1
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Gauge	11	Type	Bourdon Tube
	12	Range	0 ÷ 1.6 bar
	13	Mounting	Local
	14	Dial size	DN100 mm
	15	Dial / Pointer color / material	White / black / aluminum
	16	Pointer	Micrometric adjustable
	17	Case material	Stainless steel SS 316
	18	Ring material	Stainless steel SS 316
	19	Blow out protection	With solid baffle wall and blow-out back
	20	Lens material	Safety glass
	21	Pressure element type	Bourdon
	22	Pressure element material	SS 316L (1.4571)
	23	Socket material	Stainless Steel SS 316
	24	Movement material	Stainless Steel SS 316
	25	Connection size	1/2" NPT-M
	26	Connection type	Radial Bottom
	27	Protection degree	IP66
	28	Nominal accuracy	CLASS 1 EN837 – 1.6% on range
	29	Certification:	ATEX, Ex h Gas II 2G Ex h IIC T6 ...T1 Gb X
Accessories	30	Manifold type	5-Valves
Purchase	31	Instruments Manufacturer	WIKA
	32	Model	732.51
Notes	33		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

PRESSURE SWITCH			
General	1	Tag number	63-PS-054, 63-PS-056, 63-PS-058, 63-PS-060
	2	Service	Dryer towers pressure
	3	Quantity	4
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Instrument	11	Range	0 ÷ 16 barg
	12	Measuring element	Bourdon
	13	Set point	Adjustable
	14	Switch type	Micro switch
	15	Switch action	Hermetically sealed SPDT
	16	Switch load	Resistive
	17	Case material	SS 316
	18	Wetted parts material	Stainless steel
	19	Pressure connection size	½" NPTM
	20	Pressure connection type	Bottom
	21	Electric connection	M20x1.5
	22	Protection degree	IP66
	23	Nominal accuracy	<0,5% on range
	24	Certification:	ATEX, Zone 2, IIC, T1 Ex-d
Accessories	25	Diaphragm seal	NO
	26	Manifold	NO
Purchase	27	Manufacturer	Tema
	28	Model	PMS8.1
Notes	29		Factory set point 5 barg

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

TEMPERATURE ELEMENT + TRANSMITTER			
General	1	Tag number	63-TIT-051
	2	Service	Inlet air temperature
	3	Quantity	1
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Transmitter / Element	11	Output	4…20mA HART 7
	12	Input	Dual sensor input
	13	Instrument Range	-50 ÷ 450 °C
	14	Calibration Range	0 ÷ 100°C
	15	Accuracy	±0.15°C
	16	Case material	SS 316
	17	Execution	IP66
	18	Cable Entry	2 x M20x1.5
	19	Installation	DIN A Head mount transmitter
	20	Power supply	24 VDC
	21	Digital display	YES - LCD type integrated
	22	Certification:	ATEX, II 2G Ex db IIC T6…T1 Gb
Purchase	23	Manufacturer	EMERSON
	24	Element Model	214CRTSMA1S3MxxxxSLDFN1SR2C2B1UAE100V20Q4G1XAXW
	25	Transmitter Model	644HANDM5Q4T1HR7XA
	26	Element Type	PT 100 Class A
	27	Element Bulb	Ø6.5mm - extension 100mm
	28	Element insertion length	To be confirmed
	29	Conn. to Thermowell	1/2" NPT-M
	30	Connection to Process	316L – 1.1/2” 150# – 1/2" NPT-F
Thermowell	31	Head length	70 mm
	32	Immersion length	To be confirmed
	33	Thermowell	SS316
Notes	34		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as “NOT CONTROLLED” copy

TEMPERATURE ELEMENT + TRANSMITTER			
General	1	Tag number	63-TIT-052
	2	Service	Instrument air receiver temperature
	3	Quantity	1
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Transmitter / Element	11	Output	4…20mA HART 7
	12	Input	Dual sensor input
	13	Instrument Range	-50 ÷ 450 °C
	14	Calibration Range	0 ÷ 100°C
	15	Accuracy	±0.15°C
	16	Case material	SS 316
	17	Execution	IP66
	18	Cable Entry	2 x M20x1.5
	19	Installation	DIN A Head mount transmitter
	20	Power supply	24 VDC
	21	Digital display	YES - LCD type integrated
	22	Certification:	ATEX, II 2G Ex db IIC T6…T1 Gb
Purchase	23	Manufacturer	EMERSON
	24	Element Model	214CRTSMA1S3MxxxxSLDFN1SR2C2B1UAE100V20Q4G1XAXW
	25	Transmitter Model	644HANDM5Q4T1HR7XA
	26	Element Type	PT 100 Class A
	27	Element Bulb	Ø6.5mm - extension 100mm
	28	Element insertion length	To be confirmed
	29	Conn. to Thermowell	1/2" NPT-M
	30	Connection to Process	316L – 1.1/2” 150# – 1/2" NPT-F
Thermowell	31	Head length	70 mm
	32	Immersion length	To be confirmed
	33	Thermowell	SS316
Notes	34		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as “NOT CONTROLLED” copy

TEMPERATURE GAUGES			
General	1	Tag number	63-TI-053
	2	Service	Instrument air receiver temperature
	3	Quantity	1
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Gauge	11	Type	Bimetal
	12	Range	0 ÷ 100°C
	13	Mounting	Local
	14	Dial size	DN100 mm
	15	Dial / Pointer color / material	White / black / aluminum
	16	Case material	Stainless steel SS 304
	17	Ring material	Stainless steel SS 304
	18	Bulb Diameter	6.5mm
	19	Lens material	Safety glass
	20	Socket material	Stainless Steel SS 316
	21	Movement material	Stainless Steel SS 316
	22	Connection size	1/2" NPT-M
	23	Connection type	Back mount, adjustable
	24	Filling	None
	25	Protection degree	IP66
	26	Nominal accuracy	CLASS 1 EN837 - 1% on range
	27	Certification:	ATEX, Ex h Gas II 2G Ex h IIC T6 ...T1 Gb X
Accessories	28	Thermowell	316L – 1.1/2” 150# - 1/2" NPT-F
	29	Thermowell Head length	70 mm
	30	Thermowell Immersion length	450 mm under flange
Purchase	31	Instruments Manufacturer	WIKA
	32	Model	S55 + TW10
Notes	33		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as “NOT CONTROLLED” copy

DEW POINT ANALYZER			
General	1	Tag number	63-AIT-051
	2	Service	Package outlet dewpoint
	3	Quantity	1
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Transmitter	11	Analog output	4…20mA HART 7
	12	Calibrated Range	-100 ÷ +20°C
	13	Power supply	24 VDC
	14	Sensor	Thin film aluminum oxide
	15	Accuracy	±2°C above -100°C / ±2°C below -100°C
	16	Repeatability	±2°C above -100°C / ±0.5°C below -100°C
	17	Execution	IP66
	18	Cable Entry	M20x1.5
	19	Certification:	ATEX, II 1G Ex ia IIC T4 Ga
Probe	20	Mounting	Local
Accessories	21	Digital display	YES
	22	Isolation valves	YES
Purchase	23	Manufacturer	GE SENSING
	24	Model	HYGROPROII-2-1-0-4-0-0-0-3-0
Notes	25		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

FLOW TRANSMITTER			
General	1	Tag number	63-FIT-051
	2	Service	Package outlet flowrate
	3	Quantity	1
Process	4	Fluid	Air
	5	Operating pressure	9 barg
	6	Operating temperature	40°C
	7	Design pressure	12 barg
	8	Design temperature	90°C
	9	Area classification	Safe
	10	Ambient temperature	-8.4 ÷ 25°C
Transmitter	11	Output	4…20mA HART 7
	12	Available range	-623 ÷ 623 mbar
	13	Calibrated range	0 ÷ 500 Sm^3/h
	14	Element type	Isolating Diaphragm
	15	Wetted parts material	SS 316L
	16	Element material	SS 316L
	17	Case material	SS 316L
	18	Execution	IP65
	19	Process connections	Female thread 1/2-14 NPT-F
	20	Cable entry	M20x1.5
	21	Digital display	YES - LCD type integrated
	22	Accuracy	Better than 0,25% of adjusted span
	23	Power supply	24 VDC
	24	Certification:	ATEX, II 1/2 G Ex db IIC T6…T4 Ga/Gb
Accessories	25	Manifold Supplier	EMERSON
	26	Manifold type / Model	5-Valves / R305RC52B11
	27	Manifold mat.l Body / seal	SS316 / PTFE
	28	Restriction Orifice Plate	Yes, Model 1495
Purchase	29	Instrument Manufacturer	EMERSON
	30	Model	2051CD2A22A1KS5E8L4M5D4T1Q4Q8HR7
Notes	31		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

SOLENOID VALVE			
General	1	Tag number	63-XY-051, 63-XY-052, 63-XY-053, 63-XY-054, 63-XY-055, 63-XY-056, 63-XY-056, 63-XY-057, 63-XY-058, 63-XY-059, 63-XY-060
	2	Service	Actuated valves command
	3	Type	Solenoid valve
Body	4	Material	SS 316
	5	Connections	1/4" NPT-F
	6	Seals	NBR
Acting	7	Ways/Position	3/2
	8	Type	UNIVERSAL
Coil	9	Power supply	24Vdc
	10	Insulation class	H
	11	Protection degree	IP66
	12	Electrical connection	M20 x 1.5
	13	Power consumption	11W
Purchase	14	Manufacturer	NADI
	15	Model	C28I60D0C
	16	Certification	ATEX, Eexd IIC T6
Notes	17	Installed inside local control panel	

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

SAFETY VALVE			
General	1	Tag number	63-PSV-001, 63-PSV-002, 63-PSV-003, 63-PSV-004
	2	Service	Vessel protection
	3	Quantity	4
	4	Type	Safety relief valve
Process	5	Fluid	Air
	6	Operating pressure	12 barg
	7	Operating temperature	40°C
	8	Design pressure	12 barg
	9	Design temperature	80°C
	10	Area classification	Safe
	11	Ambient temperature	-8.4 ÷ 25°C
Design	12	Design	2014/68/EU PED
	13	Code	ISO 4126-1
	14	Design case	Fire case
	15	Inlet connection	1” ANSI 150 RF
	16	Outlet connection	2” ANSI 150 RF
	17	Orifice designation	D
	18	Set pressure	12 barg
	19	Back pressure	0
	20	Overpressure	10%
Materials	21	Diaphragm seal	NO
	22	Body	SS316
Purchase	23	Manufacturer	N.G.I.
	24	Model	G10-API
Notes	25		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as “NOT CONTROLLED” copy

SAFETY VALVE			
General	1	Tag number	63-PSV-005
	2	Service	Air receiver protection
	3	Quantity	1
	4	Type	Safety relief valve
Process	5	Fluid	Air
	6	Operating pressure	12 barg
	7	Operating temperature	40°C
	8	Design pressure	12 barg
	9	Design temperature	80°C
	10	Area classification	Safe
	11	Ambient temperature	-8.4 ÷ 25°C
Design	12	Design	2014/68/EU PED
	13	Code	ISO 4126-1
	14	Design case	Fire case
	15	Inlet connection	3” ANSI 150 RF
	16	Outlet connection	4” ANSI 150 RF
	17	Orifice designation	K
	18	Set pressure	12 barg
	19	Back pressure	0
	20	Overpressure	10%
Materials	21	Diaphragm seal	NO
	22	Body	SS316
Purchase	23	Manufacturer	N.G.I.
	24	Model	G40-API
Notes	25		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as “NOT CONTROLLED” copy

ACTUATED VALVES			
General	1	Tag number	63-XV-051, 63-XV-053
	2	Service	ON-OFF actuated valves
	3	Quantity	2
	4	Type	5-way pneumatic distributor
Process	5	Fluid	AIR
	6	Operating pressure	12 barg
	7	Operating temperature	40°C
	8	Design pressure	12 barg
	9	Design temperature	80°C
	10	Area classification	Safe
	11	Ambient temperature	-8.4 ÷ 25°C
Body	12	Size	1”
	13	Rating	NOT APPLICABLE
	14	End connections	THREADED
	15	Material	Aluminium
	16	Internals	SS 316
	17	Seat	FKM+GRAPHITE
Actuator	18	Type	NOT APPLICABLE
	19	Fail position	OPEN
Purchase	20	Manufacturer	COES
	21	Model	D7848
Notes	22		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as “NOT CONTROLLED” copy

ACTUATED VALVES			
General	1	Tag number	63-XV-052, 63-XV-054
	2	Service	ON-OFF actuated valves
	3	Quantity	2
	4	Type	3-way pneumatic distributor
Process	5	Fluid	AIR
	6	Operating pressure	12 barg
	7	Operating temperature	40°C
	8	Design pressure	12 barg
	9	Design temperature	80°C
	10	Area classification	Safe
	11	Ambient temperature	-8.4 ÷ 25°C
Body	12	Size	3/4”
	13	Rating	NOT APPLICABLE
	14	End connections	THREADED
	15	Material	Aluminium
	16	Internals	SS 316
	17	Seat	FKM+GRAPHITE
Actuator	18	Type	NOT APPLICABLE
	19	Fail position	OPEN
Purchase	20	Manufacturer	COES
	21	Model	17316
Notes	22		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as “NOT CONTROLLED” copy

ACTUATED VALVES			
General	1	Tag number	63-XV-055, 63-XV-056, 63-XV-057, 63-XV-058 63-XV-059, 63-XV-060
	2	Service	ON-OFF actuated valves
	3	Quantity	6
	4	Type	Ball valve
Process	5	Fluid	AIR
	6	Operating pressure	12 barg
	7	Operating temperature	40°C
	8	Design pressure	12 barg
	9	Design temperature	80°C
	10	Area classification	Safe
	11	Ambient temperature	-8.4 ÷ 25°C
Body	12	Size	2”
	13	Rating	150
	14	End connections	RF
	15	Material	A351 CF8M
	16	Ball	SS 316
	17	Seat	FKM+GRAPHITE
Actuator	18	Type	RACK & PINION
	19	Fail position	OPEN
Purchase	20	Manufacturer	VALPRES
	21	Model	ART.68J000
Notes	22		

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as “NOT CONTROLLED” copy