Base Load Power Hub (BLPH)

NITROGEN GENERATION PACKAGE
ATEX REGISTER

Document Number: 1724000437-MAC-LIS-00026

Document Class: 2

03	05/02/2025	Accepted for Construction (AFC)	GT	MC	TM
02	30/12/2024	Issue for Review (IFR)	GT	MC	TM
01	27/05/2024	Issue for Review (IFR)	GT	MC	TM
00	19/04/2024	Issue for Review (IFR)	GT	MC	TM
Rev.	Date	Description	Prepared	Reviewed	Approved

COES

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

No.	Revision	Tag Number	Description	Location	Manufacturer	Model Type Catalogue Number	Serial Number	ATEX Certification Marking	Reference Document	ATEX Certificate Number	Installation Zone	Notes / Comments	P.O.	Vendor	Skid / Package	Barrier Calculation Ref.	Non-Electrical Equipment	Special Conditions of safe use Applicable
1	02	64-PIT-051	Pressure transmitter	N2 Package upstream PSA Towers	EMERSON	2051CG4A02A1KS5E1M5D4T1Q4Q8HR7	24CLPC0044337	II 1/2 G Ex db IIC T6...T4 Ga/Gb	1724000437-MAC-DS-00013	KEMA 08ATEX0090X	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	YES
2	02	64-PIT-052	Pressure transmitter	N2 Package PSA Towers	EMERSON	2051CG4A02A1KS5E1M5D4T1Q4Q8HR7	24CLPC0044338	II 1/2 G Ex db IIC T6...T4 Ga/Gb	1724000437-MAC-DS-00013	KEMA 08ATEX0090X	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	YES
3	02	64-PIT-053	Pressure transmitter	N2 Package PSA Towers	EMERSON	2051CG4A02A1KS5E1M5D4T1Q4Q8HR7	24CLPC0044339	II 1/2 G Ex db IIC T6...T4 Ga/Gb	1724000437-MAC-DS-00013	KEMA 08ATEX0090X	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	YES
4	02	64-PIT-057	Pressure transmitter	N2 Package downstream Post-filters	EMERSON	2051CG4A02A1KS5E1M5D4T1Q4Q8HR7	24CLPC0044340	II 1/2 G Ex db IIC T6...T4 Ga/Gb	1724000437-MAC-DS-00013	KEMA 08ATEX0090X	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	YES
5	02	64-PIT-059	Pressure transmitter	N2 Receiver	EMERSON	2051CG4A02A1KS5E1M5D4T1Q4Q8HR7	24CLPC0044341	II 1/2 G Ex db IIC T6...T4 Ga/Gb	1724000437-MAC-DS-00013	KEMA 08ATEX0090X	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	YES
6	02	64-PDIT-056	Differential Pressure transmitter	N2 Package Post-filters	EMERSON	2051CD3A02A1KS5E1M5D4T1Q4Q8HR7	24CLPC0044344	II 1/2 G Ex db IIC T6...T4 Ga/Gb	1724000437-MAC-DS-00013	KEMA 08ATEX0090X	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	YES
7	02	64-PI-054	Pressure gauge	N2 Package PSA Towers	WIKA	233.30	8975QOD8	II 2G Ex h IIC T6 ... T1 Gb X	1724000437-MAC-DS-00013	Declaration of Conformity by Wika n. 11564220	SAFE	None	1724000437	COES Srl	U-64000	N.A.	YES	YES
8	02	64-PI-055	Pressure gauge	N2 Package PSA Towers	WIKA	233.30	8975QOD9	II 2G Ex h IIC T6 ... T1 Gb X	1724000437-MAC-DS-00013	Declaration of Conformity by Wika n. 11564220	SAFE	None	1724000437	COES Srl	U-64000	N.A.	YES	YES
9	02	64-PI-058	Pressure gauge	N2 Receiver	WIKA	233.30	8975QODA	II 2G Ex h IIC T6 ... T1 Gb X	1724000437-MAC-DS-00013	Declaration of Conformity by Wika n. 11564220	SAFE	None	1724000437	COES Srl	U-64000	N.A.	YES	YES
10	02	64-AT-051	Oxygen analyzer	N2 Package downstream PSA Towers	GE SENSING	XM02	2432080	Ex db IIC T6 Gb	1724000437-MAC-DS-00013	INERIS 21ATEX0021X	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	YES
11	02	64-XY-051	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62188/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO
12	02	64-XY-052	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62188/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO
13	02	64-XY-053	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62188/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO
14	02	64-XY-054	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62188/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO
15	02	64-XY-055	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62188/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO
16	02	64-XY-056	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62188/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO
17	02	64-XY-057	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62188/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO
18	02	64-XY-058	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62188/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO
19	02	64-XY-059	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62188/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO
20	02	64-XY-060	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62398/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO
21	02	64-XY-061	Solenoid valve	Actuated valve instrument air supply	NADI	C28I60D0C	LOT. 62398/24	Ex db IIC T6 Ga/Gb Ex tb IIIC T65°C Db Ex h IIC T6 Ga	1724000437-MAC-DS-00013	EPT 12 ATEX 0784	SAFE	None	1724000437	COES Srl	U-64000	N.A.	NO	NO