Base Load Power Hub (BLPH)

F&G FIELD EQUIPMENT

VENDOR ASSET AND TAG REGISTER

Document Number:1724000821-IN-LIS-00008

Document Class: 2

01	21/11/2024	Accepted for Construction (IFC)	L. Pizzigati	M. Ossani	S. Montanari
00	02/10/2024	Issue for Review (IFR)	L. Pizzigati	M. Ossani	S. Montanari
Rev.	Date	Description	Prepared	Reviewed	Approved

FORES ENGINEERING

This document undergoes an issuance cycle within EDMS "Fusionlive".
Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Table of Contents

SH.	DESCRIPTION	REVISIONS							
		00	01						
1	Cover	X	X						
2	Table of Contents	X	X						
3	Revision / Change Log	X	X						
4	VENDOR ASSET AND TAG REGISTER	X	X						
5	VENDOR ASSET AND TAG REGISTER	X	X						
6	VENDOR ASSET AND TAG REGISTER	X	X						
7	VENDOR ASSET AND TAG REGISTER	X	X						
8	VENDOR ASSET AND TAG REGISTER	X	X						
9	VENDOR ASSET AND TAG REGISTER		X						

This document undergoes an issuance cycle within EDMS "Fusionlive".
Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Revision / Change Log

Rev.	Description
00	Issue for Review (IFR)
01	Accepted for Construction (IFC)

HOLDS LIST

No.	Description
1.	
2.	
3.	
4.	

This document undergoes an issuance cycle within EDMS "Fusionlive".
Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Tag Number	Tag Description	Physical Class Name	Location	System/SubSystem Code	Purchase Order Number	Vendor Company Name	Manufacturer Company Name	Model Number	Equipment Manufacturer Serial Number	Model Part No	Hazardous Area Equip Relevant	Hazardous Area Certificate Standard	Hazardous Area Certifying Authority	Hazardous Area Certificate Number	Atex Classification	Explosion Protection Examination Certificate Document Number	Layout Drawing	Datasheet	Assembly/Dimensional Drawing	General Arrangement	Operating & Maintenance Manual	Wiring Diagram	Spare Parts List	Lubricant Document Reference	Criticality	Remarks
950-SDZ-04201	FZ-04 SMOKE DETECT. IN B-400 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-04 B-400 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4050816	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04202	FZ-04 SMOKE DETECT. IN B-400 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-04 B-400 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4050799	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04203	FZ-04 SMOKE DETECT. IN B-400 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-04 B-400 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4050827	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04207	FZ-04 SMOKE DETECT. IN B-300 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-04 B-300 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4050834	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04208	FZ-04 SMOKE DETECT. IN B-300 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-04 B-300 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051785	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04209	FZ-04 SMOKE DETECT. IN B-300 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-04 B-300 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4050815	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04213	FZ-04 SMOKE DETECT. IN B-200 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-04 B-200 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051769	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04214	FZ-04 SMOKE DETECT. IN B-200 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-04 B-200 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051786	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04215	FZ-04 SMOKE DETECT. IN B-200 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-04 B-200 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051705	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-06201	FZ-06 SMOKE DETECT. IN B-100 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-06 B-100 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051704	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-06202	FZ-06 SMOKE DETECT. IN B-100 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-06 B-100 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051745	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-06203	FZ-06 SMOKE DETECT. IN B-100 HVAC AIR INTAKE	SMOKE DETECTOR	FZ-06 B-100 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051716	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04204	FZ-04 SMOKE DETECT. IN B-400 I&T EQUIP. ROOM	SMOKE DETECTOR	FZ-04 B-400 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051764	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04205	FZ-04 SMOKE DETECT. IN B-400 I&T EQUIP. ROOM	SMOKE DETECTOR	FZ-04 B-400 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051760	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04206	FZ-04 SMOKE DETECT. IN B-400 I&T EQUIP. ROOM	SMOKE DETECTOR	FZ-04 B-400 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051754	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04210	FZ-04 SMOKE DETECT. IN B-300 AC UPS ROOM	SMOKE DETECTOR	FZ-04 B-300 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051736	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04211	FZ-04 SMOKE DETECT. IN B-300 AC UPS ROOM	SMOKE DETECTOR	FZ-04 B-300 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051777	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04212	FZ-04 SMOKE DETECT. IN B-300 AC UPS ROOM	SMOKE DETECTOR	FZ-04 B-300 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051708	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04216	FZ-04 SMOKE DETECT. IN B-200 LV SWGR ROOM	SMOKE DETECTOR	FZ-04 B-200 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051744	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04217	FZ-04 SMOKE DETECT. IN B-200 LV SWGR ROOM	SMOKE DETECTOR	FZ-04 B-200 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051770	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-04218	FZ-04 SMOKE DETECT. IN B-200 LV SWGR ROOM	SMOKE DETECTOR	FZ-04 B-200 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051724	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-06204	FZ-06 SMOKE DETECT. IN B-100 HV/MV SWGR ROOM	SMOKE DETECTOR	FZ-06 B-100 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051762	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-06205	FZ-06 SMOKE DETECT. IN B-100 HV/MV SWGR ROOM	SMOKE DETECTOR	FZ-06 B-100 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051768	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-SDZ-06206	FZ-06 SMOKE DETECT. IN B-100 HV/MV SWGR ROOM	SMOKE DETECTOR	FZ-06 B-100 AMBIENT	950	1724000821	Foxes Engineering	TYCO	MR601TEx	4051782	MR601TEx		EN IEC 60079-0:2018	SGS Finke Oy	BAS 01 ATEX 1134 X	II 1 GD	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02101	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2193	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02102	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2196	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02103	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2197	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02104	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1620	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02105	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2185	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02106	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2201	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02107	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2206	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02108	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2198	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02109	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2203	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02110	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2204	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02111	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1618	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02112	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2192	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02113	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2207	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02114	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2200	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02115	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1615	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02116	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	HYDROGEN POINT DETECTORS	H2 QD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2208	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04201	FZ-04 H2 DETECT. IN B-400 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 QD FZ-04 B-400 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1611	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04202	FZ-04 H2 DETECT. IN B-400 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 QD FZ-04 B-400 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1625	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04203	FZ-04 H2 DETECT. IN B-400 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 QD FZ-04 B-400 HVAC AIR INTAKE	950	1724000821	Foxes Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1631	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0624202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		

Tag Number	Tag Description	Physical Class Name	Location	System/SubSystem Code	Purchase Order Number	Vendor Company Name	Manufacturer Company Name	Model Number	Equipment Manufacturer Serial Number	Model Part No	Hazardous Area Equip Relevant	Hazardous Area Certificate Standard	Hazardous Area Certifying Authority	Hazardous Area Certificate Number	Atex Classification	Explosion Protection Examination Certificate Document Number	Layout Drawing	Datasheet	Assembly/Dimensional Drawing	General Arrangement	Operating & Maintenance Manual	Wiring Diagram	Spare Parts List	Lubricant Document Reference	Criticality	Remarks
950-GDZ-04204	FZ-04 H2 DETECT. IN B-400 I&T EQUIP. ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-400 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2205	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04205	FZ-04 H2 DETECT. IN B-400 I&T EQUIP. ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-400 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2202	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04206	FZ-04 H2 DETECT. IN B-400 I&T EQUIP. ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-400 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1613	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04207	FZ-04 H2 DETECT. IN B-300 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-300 HVAC AIR INTAKE	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1635	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04208	FZ-04 H2 DETECT. IN B-300 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-300 HVAC AIR INTAKE	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-0199	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04209	FZ-04 H2 DETECT. IN B-300 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-300 HVAC AIR INTAKE	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1633	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04210	FZ-04 H2 DETECT. IN B-300 AC UPS ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-300 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1619	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04211	FZ-04 H2 DETECT. IN B-300 AC UPS ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-300 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1628	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04212	FZ-04 H2 DETECT. IN B-300 AC UPS ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-300 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1627	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04213	FZ-04 H2 DETECT. IN B-200 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-200 HVAC AIR INTAKE	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-0202	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04214	FZ-04 H2 DETECT. IN B-200 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-200 HVAC AIR INTAKE	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1616	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04215	FZ-04 H2 DETECT. IN B-200 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-200 HVAC AIR INTAKE	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1621	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04216	FZ-04 H2 DETECT. IN B-200 LV SWGR ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-200 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1614	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04217	FZ-04 H2 DETECT. IN B-200 LV SWGR ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-200 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1610	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-04218	FZ-04 H2 DETECT. IN B-200 LV SWGR ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-04 B-200 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTC-2199	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-05101	FZ-05 H2 DETECT. IN BESS AREA	HYDROGEN POINT DETECTORS	H2 GD FZ-05 BESS AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1626	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-05102	FZ-05 H2 DETECT. IN BESS AREA	HYDROGEN POINT DETECTORS	H2 GD FZ-05 BESS AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1623	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-05103	FZ-05 H2 DETECT. IN BESS AREA	HYDROGEN POINT DETECTORS	H2 GD FZ-05 BESS AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1622	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-05104	FZ-05 H2 DETECT. IN BESS AREA	HYDROGEN POINT DETECTORS	H2 GD FZ-05 BESS AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARSD-0457	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-05105	FZ-05 H2 DETECT. IN BESS AREA	HYDROGEN POINT DETECTORS	H2 GD FZ-05 BESS AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1612	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-05106	FZ-05 H2 DETECT. IN BESS AREA	HYDROGEN POINT DETECTORS	H2 GD FZ-05 BESS AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1617	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-06201	FZ-06 H2 DETECT. IN B-100 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 GD FZ-06 B-100 HVAC AIR INTAKE	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1634	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-06202	FZ-06 H2 DETECT. IN B-100 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 GD FZ-06 B-100 HVAC AIR INTAKE	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1629	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-06203	FZ-06 H2 DETECT. IN B-100 HVAC AIR INTAKE	HYDROGEN POINT DETECTORS	H2 GD FZ-06 B-100 HVAC AIR INTAKE	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1639	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-06204	FZ-06 H2 DETECT. IN B-100 HV/MV SWGR ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-06 B-100 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1637	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-06205	FZ-06 H2 DETECT. IN B-100 HV/MV SWGR ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-06 B-100 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-0204	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-06206	FZ-06 H2 DETECT. IN B-100 HV/MV SWGR ROOM	HYDROGEN POINT DETECTORS	H2 GD FZ-06 B-100 AMBIENT	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARSD-0466	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-03104	FZ-03 H2 DETECT. IN ELECTROLYZER PACKAGE AREA	HYDROGEN POINT DETECTORS	H2 GD FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1624	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-03105	FZ-03 H2 DETECT. IN ELECTROLYZER PACKAGE AREA	HYDROGEN POINT DETECTORS	H2 GD FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-1630	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-01103	FZ-03 H2 DETECT. IN ELECTROLYZER PACKAGE AREA	HYDROGEN POINT DETECTORS	H2 GD FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8200 CAT DQ d S 4-20/HART®	ARTB-0194	Polytron® 8200 CAT DQ d S 4-20/HART®		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR) DEMKO 09 ATEX 0924202X (SENSOR) CML 18ATEX 1320X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-01101	FZ-01 H2 DETECT. IN FUEL CELL PACKAGE AREA	ULTRASONIC GAS DETECTOR	H2 GD FZ-01 FUEL CELL PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8900 UGLD d S 4-20/HART® Relay	ARTA-1680	Polytron® 8900 UGLD d S 4-20/HART® Relay		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-01102	FZ-01 H2 DETECT. IN FUEL CELL PACKAGE AREA	ULTRASONIC GAS DETECTOR	H2 GD FZ-01 FUEL CELL PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8900 UGLD d S 4-20/HART® Relay	ARTA-1685	Polytron® 8900 UGLD d S 4-20/HART® Relay		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02117	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	ULTRASONIC GAS DETECTOR	H2 GD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8900 UGLD d S 4-20/HART® Relay	ARTA-1682	Polytron® 8900 UGLD d S 4-20/HART® Relay		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02118	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	ULTRASONIC GAS DETECTOR	H2 GD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8900 UGLD d S 4-20/HART® Relay	ARTA-1676	Polytron® 8900 UGLD d S 4-20/HART® Relay		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GKDZ-02119	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	ULTRASONIC GAS DETECTOR	H2 GD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8900 UGLD d S 4-20/HART® Relay	ARTA-1684	Polytron® 8900 UGLD d S 4-20/HART® Relay		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-02120	FZ-02 H2 DETECT. IN HYDROGEN STORAGE VESSELS AREA	ULTRASONIC GAS DETECTOR	H2 GD FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8900 UGLD d S 4-20/HART® Relay	ARTA-1687	Polytron® 8900 UGLD d S 4-20/HART® Relay		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-03101	FZ-03 H2 DETECT. IN ELECTROLYZER PACKAGE AREA	ULTRASONIC GAS DETECTOR	H2 GD FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8900 UGLD d S 4-20/HART® Relay	ARTA-1688	Polytron® 8900 UGLD d S 4-20/HART® Relay		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-03102	FZ-03 H2 DETECT. IN ELECTROLYZER PACKAGE AREA	ULTRASONIC GAS DETECTOR	H2 GD FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8900 UGLD d S 4-20/HART® Relay	ARTA-1683	Polytron® 8900 UGLD d S 4-20/HART® Relay		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-03103	FZ-03 H2 DETECT. IN ELECTROLYZER PACKAGE AREA	ULTRASONIC GAS DETECTOR	H2 GD FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron® 8900 UGLD d S 4-20/HART® Relay	ARTA-1681	Polytron® 8900 UGLD d S 4-20/HART® Relay		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-03107	FZ-03 OXYGEN IN ELECTROLYZER PACKAGE AREA	OXYGEN POINT DETECTORS	O2 DET. FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron 8100 EC d S 4-20/Hart	ARTA-4693	Polytron 8100 EC d S 4-20/Hart		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-03108	FZ-03 OXYGEN IN ELECTROLYZER PACKAGE AREA	OXYGEN POINT DETECTORS	O2 DET. FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron 8100 EC d S 4-20/Hart	ARTA-4680	Polytron 8100 EC d S 4-20/Hart		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-GDZ-03109	FZ-03 OXYGEN IN ELECTROLYZER PACKAGE AREA	OXYGEN POINT DETECTORS	O2 DET. FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	Dräger	Polytron 8100 EC d S 4-20/Hart	ARTA-4689	Polytron 8100 EC d S 4-20/Hart		EN IEC 60079-0:2018	PTB	PTB 11 ATEX 1005X (TR) BVS 13 ATEX G 001X (TR)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-01101	FZ-01 FLAME DETECT. IN FUEL CELL PACKAGE AREA	FLAME DETECTOR	FZ-01 FUEL CELL PK AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		

Tag Number	Tag Description	Physical Class Name	Location	System/SubSystem Code	Purchase Order Number	Vendor Company Name	Manufacturer Company Name	Model Number	Equipment Manufacturer Serial Number	Model Part No	Hazardous Area Equip Relevant	Hazardous Area Certificate Standard	Hazardous Area Certifying Authority	Hazardous Area Certificate Number	Atex Classification	Explosion Protection Examination Certificate Document Number	Layout Drawing	Datasheet	Assembly/Dimensional Drawing	General Arrangement	Operating & Maintenance Manual	Wiring Diagram	Spare Parts List	Lubricant Document Reference	Criticality	Remarks
950-FDZ-01102	FZ-01 FLAME DETECT. IN FUEL CELL PACKAGE AREA	FLAME DETECTOR	FZ-01 FUEL CELL PK AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-01103	FZ-01 FLAME DETECT. IN FUEL CELL PACKAGE AREA	FLAME DETECTOR	FZ-01 FUEL CELL PK AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-01104	FZ-01 FLAME DETECT. IN FUEL CELL PACKAGE AREA	FLAME DETECTOR	FZ-01 FUEL CELL PK AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-02101	FZ-02 FLAME DETECT. IN HYDROGEN STORAGE VESSELS AREA	FLAME DETECTOR	FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-02102	FZ-02 FLAME DETECT. IN HYDROGEN STORAGE VESSELS AREA	FLAME DETECTOR	FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-02103	FZ-02 FLAME DETECT. IN HYDROGEN STORAGE VESSELS AREA	FLAME DETECTOR	FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-02104	FZ-02 FLAME DETECT. IN HYDROGEN STORAGE VESSELS AREA	FLAME DETECTOR	FZ-02 H2 STORAGE VESSELS AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-03101	FZ-03 FLAME DETECT. IN ELECTROLYZER PACKAGE AREA	FLAME DETECTOR	FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-03102	FZ-03 FLAME DETECT. IN ELECTROLYZER PACKAGE AREA	FLAME DETECTOR	FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-03103	FZ-03 FLAME DETECT. IN ELECTROLYZER PACKAGE AREA	FLAME DETECTOR	FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-03104	FZ-03 FLAME DETECT. IN ELECTROLYZER PACKAGE AREA	FLAME DETECTOR	FZ-03 ELECTROLYZER PK AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-04101	FZ-04 FLAME DETECT. IN B-400/B-300/B-200 AREA	FLAME DETECTOR	FZ-04 B-400/B-300/B-200 AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-04102	FZ-04 FLAME DETECT. IN B-400/B-300/B-200 AREA	FLAME DETECTOR	FZ-04 B-400/B-300/B-200 AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-04103	FZ-04 FLAME DETECT. IN B-400/B-300/B-200 AREA	FLAME DETECTOR	FZ-04 B-400/B-300/B-200 AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-04104	FZ-04 FLAME DETECT. IN B-400/B-300/B-200 AREA	FLAME DETECTOR	FZ-04 B-400/B-300/B-200 AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-05101	FZ-05 FLAME DETECT. IN BESS AREA	FLAME DETECTOR	FZ-05 BESS AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-05102	FZ-05 FLAME DETECT. IN BESS AREA	FLAME DETECTOR	FZ-05 BESS AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-05103	FZ-05 FLAME DETECT. IN BESS AREA	FLAME DETECTOR	FZ-05 BESS AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-05104	FZ-05 FLAME DETECT. IN BESS AREA	FLAME DETECTOR	FZ-05 BESS AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-06101	FZ-06 FLAME DETECT. IN B-100/TRANSFORMER AREA	FLAME DETECTOR	FZ-06 B-100 AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-FDZ-06102	FZ-06 FLAME DETECT. IN B-100/TRANSFORMER AREA	FLAME DETECTOR	FZ-06 B-100 AREA	950	1724000821	Fores Engineering	FGD	FlameSpec FLS-UV-IR-AS11	Note1	FlameSpec FLS-UV-IR-AS11		EN 60079-0:2012/A11:2013	ICQC	ICQC 19 ATEX 0424X (SENSOR) TPS19 ATEX 105708 0001X (PLUG) INERIS 14 ATEX 0029X (REDUCTION)	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-01101	FZ-01 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-01 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/201	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-01102	FZ-01 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-01 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/202	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-01103	FZ-01 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-01 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/203	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-02101	Z-02 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-02 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/204	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-03101	FZ-03 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-03 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/205	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-03102	FZ-03 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-03 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/206	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-03103	FZ-03 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-03 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/207	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-03104	FZ-03 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-03 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/208	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-04101	FZ-04 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-04 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/209	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-04102	FZ-04 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-04 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/10	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-04201	FZ-04 MANUAL FIRE ALARM (MFA) B-400 I&T EQUIP. ROOM	MANUAL FIRE ALARM	FZ-04 MFA ACTIVATION - B-400 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/11	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-04202	FZ-04 MANUAL FIRE ALARM (MFA) B-300 AC UPS ROOM	MANUAL FIRE ALARM	FZ-04 MFA ACTIVATION - B-300 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/12	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-04203	FZ-04 MANUAL FIRE ALARM (MFA) B-200 LV SWGR ROOM	MANUAL FIRE ALARM	FZ-04 MFA ACTIVATION - B-200 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/13	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-05101	FZ-05 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-05 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/14	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-05102	FZ-05 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-05 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/15	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-05103	FZ-05 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-05 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/16	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-05104	FZ-05 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-05 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/17	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-06101	FZ-06 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-06 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/18	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-06102	FZ-06 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-06 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/19	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-06201	FZ-06 MANUAL FIRE ALARM (MFA) B-100 HV/MV SWGR ROOM	MANUAL FIRE ALARM	FZ-06 MFA ACTIVATION - B-100 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/20	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MFA-07101	FZ-07 MANUAL FIRE ALARM (MFA)	MANUAL FIRE ALARM	FZ-07 MFA ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/20/21	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ASD-01101	FZ-01 ABANDON SHUTDOWN ACTIVATION (ASD)	ABANDON ACTIVATION	FZ-01 ABANDON SHUTDOWN ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	22542045/301	SM87PBL		EN IEC 60079-0:2018	SGS Fimko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		

Tag Number	Tag Description	Physical Class Name	Location	System/SubSystem Code	Purchase Order Number	Vendor Company Name	Manufacturer Company Name	Model Number	Equipment Manufacturer Serial Number	Model Part No	Hazardous Area Equip Relevant	Hazardous Area Certificate Standard	Hazardous Area Certifying Authority	Hazardous Area Certificate Number	Atex Classification	Explosion Protection Examination Certificate Document Number	Layout Drawing	Datasheet	Assembly/Dimensional Drawing	General Arrangement	Operating & Maintenance Manual	Wiring Diagram	Spare Parts List	Lubricant Document Reference	Criticality	Remarks
950-ASD-03101	FZ-03 ABANDON SHUTDOWN ACTIVATION (ASD)	ABANDON ACTIVATION	FZ-03 ABANDON SHUTDOWN ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/2	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ASD-04101	FZ-04 ABANDON SHUTDOWN ACTIVATION (ASD)	ABANDON ACTIVATION	FZ-04 ABANDON SHUTDOWN ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/3	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ASD-06101	FZ-06 ABANDON SHUTDOWN ACTIVATION (ASD)	ABANDON ACTIVATION	FZ-06 ABANDON SHUTDOWN ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/4	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ASD-07101	FZ-07 ABANDON SHUTDOWN ACTIVATION (ASD)	ABANDON ACTIVATION	FZ-07 ABANDON SHUTDOWN ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/5	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MOB-01101	FZ-01 MAN OVER BOARD ACTIVATION (MOB)	MAN OVER BOARD ACTIVATION	FZ-01 MAN OVER BOARD ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/6	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MOB-03101	FZ-03 MAN OVER BOARD ACTIVATION (MOB)	MAN OVER BOARD ACTIVATION	FZ-03 MAN OVER BOARD ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/7	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MOB-04101	FZ-04 MAN OVER BOARD ACTIVATION (MOB)	MAN OVER BOARD ACTIVATION	FZ-04 MAN OVER BOARD ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/8	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MOB-06101	FZ-06 MAN OVER BOARD ACTIVATION (MOB)	MAN OVER BOARD ACTIVATION	FZ-06 MAN OVER BOARD ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/9	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-MOB-07101	FZ-07 MAN OVER BOARD ACTIVATION (MOB)	MAN OVER BOARD ACTIVATION	FZ-07 MAN OVER BOARD ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/10	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ESD-01101	FZ-01 ESD-1 PUSH BUTTON ACTIVATION (ESD)	EMERGENCY SHUTDOWN ACTIVATION	FZ-01 ESD-1 PUSH BUTTON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/11	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ESD-03101	FZ-03 ESD-1 PUSH BUTTON ACTIVATION (ESD)	EMERGENCY SHUTDOWN ACTIVATION	FZ-03 ESD-1 PUSH BUTTON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/12	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ESD-04101	FZ-04 ESD-1 PUSH BUTTON ACTIVATION (ESD)	EMERGENCY SHUTDOWN ACTIVATION	FZ-04 ESD-1 PUSH BUTTON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/13	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ESD-06101	FZ-06 ESD-1 PUSH BUTTON ACTIVATION (ESD)	EMERGENCY SHUTDOWN ACTIVATION	FZ-06 ESD-1 PUSH BUTTON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/14	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ESD-07101	FZ-07 ESD-1 PUSH BUTTON ACTIVATION (ESD)	EMERGENCY SHUTDOWN ACTIVATION	FZ-07 ESD-1 PUSH BUTTON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/15	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ESDD-01101	FZ-01 DEPRESS. EMERGENCY SHUT DOWN (ESDD)	EMERGENCY SHUTDOWN DEPRESSURIZATION ACTIVATION	FZ-01 ESD-1D PUSH BUTTON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/16	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ESDD-03101	FZ-03 DEPRESS. EMERGENCY SHUT DOWN (ESDD)	EMERGENCY SHUTDOWN DEPRESSURIZATION ACTIVATION	FZ-03 ESD-1D PUSH BUTTON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/17	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ESDD-04101	FZ-04 DEPRESS. EMERGENCY SHUT DOWN (ESDD)	EMERGENCY SHUTDOWN DEPRESSURIZATION ACTIVATION	FZ-04 ESD-1D PUSH BUTTON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/18	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ESDD-06101	FZ-06 DEPRESS. EMERGENCY SHUT DOWN (ESDD)	EMERGENCY SHUTDOWN DEPRESSURIZATION ACTIVATION	FZ-06 ESD-1D PUSH BUTTON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/19	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-ESDD-07101	FZ-07 DEPRESS. EMERGENCY SHUT DOWN (ESDD)	EMERGENCY SHUTDOWN DEPRESSURIZATION ACTIVATION	FZ-07 ESD-1D PUSH BUTTON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87PBL	225420465/30/20	SM87PBL		EN IEC 60079-0:2018	SGS Finko Oy	Baseefa 03 ATEX 0075 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-01101	FZ-01 OPTICAL EXP GAS ALARM	FLAMMABLE GAS ALARM	FZ-01 GAS BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/1	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-02101	FZ-02 OPTICAL EXP GAS ALARM	FLAMMABLE GAS ALARM	FZ-02 GAS BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/2	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-03101	FZ-03 OPTICAL EXP GAS ALARM	FLAMMABLE GAS ALARM	FZ-03 GAS BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/3	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-03103	FZ-03 OPTICAL EXP GAS ALARM	FLAMMABLE GAS ALARM	FZ-03 GAS BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/4	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-04101	FZ-04 OPTICAL EXP GAS ALARM	FLAMMABLE GAS ALARM	FZ-04 GAS BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/5	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-04103	FZ-04 OPTICAL EXP GAS ALARM	FLAMMABLE GAS ALARM	FZ-04 GAS BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/6	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-04201	FZ-04 OPTICAL EXP GAS ALARM B-400 I&T EQUIP. ROOM	FLAMMABLE GAS ALARM	FZ-04 GAS BEACON ACT. - B-400 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/7	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-04203	FZ-04 OPTICAL EXP GAS ALARM B-300 AC UPS ROOM	FLAMMABLE GAS ALARM	FZ-04 GAS BEACON ACT. - B-300 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/8	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-04205	FZ-04 OPTICAL EXP GAS ALARM B-200 LV SWGR ROOM	FLAMMABLE GAS ALARM	FZ-04 GAS BEACON ACT. - B-200 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/9	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-06101	FZ-06 OPTICAL EXP GAS ALARM	FLAMMABLE GAS ALARM	FZ-06 GAS BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/10	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-06103	FZ-06 OPTICAL EXP GAS ALARM	FLAMMABLE GAS ALARM	FZ-06 GAS BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/11	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-06001	FZ-06 OPTICAL EXP GAS ALARM B-100 HV/MV SWGR ROOM	FLAMMABLE GAS ALARM	FZ-06 GAS BEACON ACT. - B-100 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/12	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-07101	FZ-07 OPTICAL EXP GAS ALARM	FLAMMABLE GAS ALARM	FZ-07 GAS BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/40/13	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-01102	FZ-01 OPTICAL FIRE ALARM	FIRE FLASH BEACON	FZ-01 FIRE BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/1	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-02102	FZ-02 OPTICAL FIRE ALARM	FIRE FLASH BEACON	FZ-02 FIRE BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/2	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-03102	FZ-03 OPTICAL FIRE ALARM	FIRE FLASH BEACON	FZ-03 FIRE BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/3	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-03104	FZ-03 OPTICAL FIRE ALARM	FIRE FLASH BEACON	FZ-03 FIRE BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/4	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-04102	FZ-04 OPTICAL FIRE ALARM	FIRE FLASH BEACON	FZ-04 FIRE BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/5	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-04104	FZ-04 OPTICAL FIRE ALARM	FIRE FLASH BEACON	FZ-04 FIRE BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/6	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-04202	FZ-04 OPTICAL FIRE ALARM B-400 I&T EQUIP. ROOM	FIRE FLASH BEACON	FZ-04 FIRE BEACON ACT. - B-400 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/7	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-04204	FZ-04 OPTICAL FIRE ALARM B-300 AC UPS ROOM	FIRE FLASH BEACON	FZ-04 FIRE BEACON ACT. - B-300 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/8	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-04206	FZ-04 OPTICAL FIRE ALARM B-200 LV SWGR ROOM	FIRE FLASH BEACON	FZ-04 FIRE BEACON ACT. - B-200 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/9	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-06102	FZ-06 OPTICAL FIRE ALARM	FIRE FLASH BEACON	FZ-06 FIRE BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/10	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-06104	FZ-06 OPTICAL FIRE ALARM	FIRE FLASH BEACON	FZ-06 FIRE BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/11	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		

Tag Number	Tag Description	Physical Class Name	Location	System/SubSystem Code	Purchase Order Number	Vendor Company Name	Manufacturer Company Name	Model Number	Equipment Manufacturer Serial Number	Model Part No	Hazardous Area Equip Relevant	Hazardous Area Certificate Standard	Hazardous Area Certifying Authority	Hazardous Area Certificate Number	Atex Classification	Explosion Protection Examination Certificate Document Number	Layout Drawing	Datasheet	Assembly/Dimensional Drawing	General Arrangement	Operating & Maintenance Manual	Wiring Diagram	Spare Parts List	Lubricant Document Reference	Criticality	Remarks
950-XL-06202	FZ-06 OPTICAL FIRE ALARM B-100 HV/MV SWGR ROOM	FIRE FLASH BEACON	FZ-06 FIRE BEACON ACT. - B-100 INDOOR	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/12	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XL-07102	FZ-07 OPTICAL FIRE ALARM	FIRE FLASH BEACON	FZ-07 FIRE BEACON ACTIVATION	950	1724000821	Fores Engineering	MEDC	SM87LEDS	225420465/50/13	SM87LEDS		EN 60079-0:2009	Baseefa	Baseefa 03 ATEX 0222	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-01101	FZ-01 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-01 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/01	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-01102	FZ-01 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-01 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/02	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-02101	FZ-02 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-02 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/03	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-03101	FZ-03 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-03 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/04	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-03102	FZ-03 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-03 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/05	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-04101	FZ-04 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-04 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/06	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-04102	FZ-04 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-04 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/07	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-04201	FZ-04 ACOUSTIC FIRE&GAS ALARM B-400 I&T EQUIP. ROOM	SOUNDER	FZ-04 SOUNDER ACT. - B-400 INDOOR	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/08	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-04202	FZ-04 ACOUSTIC FIRE&GAS ALARM B-300 AC UPS ROOM	SOUNDER	FZ-04 SOUNDER ACT. - B-300 INDOOR	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/09	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-04203	FZ-04 ACOUSTIC FIRE&GAS ALARM B-200 LV SWGR ROOM	SOUNDER	FZ-04 SOUNDER ACT. - B-200 INDOOR	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/10	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-05101	FZ-05 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-05 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/11	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-05102	FZ-05 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-05 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/12	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-05103	FZ-05 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-05 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/13	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-05104	FZ-05 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-05 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/14	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-06101	FZ-06 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-06 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/15	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-06201	FZ-06 ACOUSTIC FIRE&GAS ALARM B-100 HV/MV SWGR ROOM	SOUNDER	FZ-06 SOUNDER ACT. - B-100 INDOOR	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/16	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
950-XZ-07101	FZ-06 ACOUSTIC FIRE&GAS ALARM	SOUNDER	FZ-07 SOUNDER ACTIVATION	950	1724000821	Fores Engineering	MEDC	DB3BM	225420465/60/17	DB3BM		EN IEC 60079-0:2018	UL International Demko	UL 21 ATEX 2559X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-001A	B-100 Fire Damper AHU1 Inlet Air	PUSH BUTTON DPDT CONTACT	B-100 Fire Damper AHU1 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11391	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-001B	B-100 Fire Damper AHU1 Inlet Air	PUSH BUTTON DPDT CONTACT	B-100 Fire Damper AHU1 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11392	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-002A	B-100 Fire Damper AHU2 Inlet Air	PUSH BUTTON DPDT CONTACT	B-100 Fire Damper AHU2 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11393	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-002B	B-100 Fire Damper AHU2 Inlet Air	PUSH BUTTON DPDT CONTACT	B-100 Fire Damper AHU2 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11394	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-003A	B-100 Fire Damper Exhaust Air	PUSH BUTTON DPDT CONTACT	B-100 Fire Damper Exhaust Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11395	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-003B	B-100 Fire Damper Exhaust Air	PUSH BUTTON DPDT CONTACT	B-100 Fire Damper Exhaust Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11396	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-004A	B-200 Fire Damper AHU3 Inlet Air	PUSH BUTTON DPDT CONTACT	B-200 Fire Damper AHU3 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11397	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-004B	B-200 Fire Damper AHU3 Inlet Air	PUSH BUTTON DPDT CONTACT	B-200 Fire Damper AHU3 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11398	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-005A	B-200 Fire Damper AHU4 Inlet Air	PUSH BUTTON DPDT CONTACT	B-200 Fire Damper AHU4 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11399	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-005B	B-200 Fire Damper AHU4 Inlet Air	PUSH BUTTON DPDT CONTACT	B-200 Fire Damper AHU4 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11400	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-006A	B-200 Fire Damper Exhaust Air	PUSH BUTTON DPDT CONTACT	B-200 Fire Damper Exhaust Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11401	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-006B	B-200 Fire Damper Exhaust Air	PUSH BUTTON DPDT CONTACT	B-200 Fire Damper Exhaust Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11402	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-007A	B-300 Fire Damper AHU5 Inlet Air	PUSH BUTTON DPDT CONTACT	B-300 Fire Damper AHU5 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11403	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-007B	B-300 Fire Damper AHU5 Inlet Air	PUSH BUTTON DPDT CONTACT	B-300 Fire Damper AHU5 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11404	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-008A	B-300 Fire Damper AHU5 Return Air	PUSH BUTTON DPDT CONTACT	B-300 Fire Damper AHU5 Return Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11405	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-008B	B-300 Fire Damper AHU5 Return Air	PUSH BUTTON DPDT CONTACT	B-300 Fire Damper AHU5 Return Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11406	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-009A	B-300 Fire Damper AHU6 Inlet Air	PUSH BUTTON DPDT CONTACT	B-300 Fire Damper AHU6 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11407	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-009B	B-300 Fire Damper AHU6 Inlet Air	PUSH BUTTON DPDT CONTACT	B-300 Fire Damper AHU6 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11408	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-010A	B-300 Fire Damper AHU6 Return Air	PUSH BUTTON DPDT CONTACT	B-300 Fire Damper AHU6 Return Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11409	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-010B	B-300 Fire Damper AHU6 Return Air	PUSH BUTTON DPDT CONTACT	B-300 Fire Damper AHU6 Return Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11410	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-011A	B-300 Fire Damper Exhaust Air	PUSH BUTTON DPDT CONTACT	B-300 Fire Damper Exhaust Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11411	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-011B	B-300 Fire Damper Exhaust Air	PUSH BUTTON DPDT CONTACT	B-300 Fire Damper Exhaust Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11412	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-012A	B-400 Fire Damper AHU7 Inlet Air	PUSH BUTTON DPDT CONTACT	B-400 Fire Damper AHU7 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11413	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-012B	B-400 Fire Damper AHU7 Inlet Air	PUSH BUTTON DPDT CONTACT	B-400 Fire Damper AHU7 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11414	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		

Tag Number	Tag Description	Physical Class Name	Location	System/SubSystem Code	Purchase Order Number	Vendor Company Name	Manufacturer Company Name	Model Number	Equipment Manufacturer Serial Number	Model Part No	Hazardous Area Equip Relevant	Hazardous Area Certificate Standard	Hazardous Area Certifying Authority	Hazardous Area Certificate Number	Atex Classification	Explosion Protection Examination Certificate Document Number	Layout Drawing	Datasheet	Assembly/Dimensional Drawing	General Arrangement	Operating & Maintenance Manual	Wiring Diagram	Spare Parts List	Lubricant Document Reference	Criticality	Remarks
77-HS-013A	B-400 Fire Damper AHU7 Return Air	PUSH BUTTON DPDT CONTACT	B-400 Fire Damper AHU7 Return Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11415	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-013B	B-400 Fire Damper AHU7 Return Air	PUSH BUTTON DPDT CONTACT	B-400 Fire Damper AHU7 Return Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11416	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-014A	B-400 Fire Damper AHU8 Inlet Air	PUSH BUTTON DPDT CONTACT	B-400 Fire Damper AHU8 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11417	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-014B	B-400 Fire Damper AHU8 Inlet Air	PUSH BUTTON DPDT CONTACT	B-400 Fire Damper AHU8 Inlet Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11418	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-015A	B-400 Fire Damper AHU8 Return Air	PUSH BUTTON DPDT CONTACT	B-400 Fire Damper AHU8 Return Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11419	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-015B	B-400 Fire Damper AHU8 Return Air	PUSH BUTTON DPDT CONTACT	B-400 Fire Damper AHU8 Return Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11420	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-016A	B-400 Fire Damper Exhaust Air	PUSH BUTTON DPDT CONTACT	B-400 Fire Damper Exhaust Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11421	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
77-HS-016B	B-400 Fire Damper Exhaust Air	PUSH BUTTON DPDT CONTACT	B-400 Fire Damper Exhaust Air	950	1724000821	Fores Engineering	EATON	GHG 432	24-11422	GHG 432		EN IEC 60079-0:2018	DEKRA	BVS 22 ATEX E032 X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	1724000821-IN-DA-00003	1724000821-IN-DA-00003	1724000821-IN-MAN-00010	1724000821-IN-DA-00003	1724000821-COM-LIS-00011	NOT APPLICABLE		
NOT APPLICABLE	NOT APPLICABLE	FLAME SIMULATOR	NOT APPLICABLE	950	1724000821	Fores Engineering	FDG	FlameSpec FLS-FSIM-UV/IR-KIT	1544	FlameSpec FLS-FSIM-UV/IR-KIT		EN 60079-0:2012/A11:2013	ICQC	ICQC 20 ATEX 0447X	II 2 G	1724000821-IN-LIS-00009-01		1724000821-IN-DS-00004	NOT APPLICABLE	NOT APPLICABLE	NOT APPLICABLE	NOT APPLICABLE	NOT APPLICABLE	NOT APPLICABLE		