Base Load Power Hub (BLPH)

ATEX REGISTER - HYDROGEN VENT

Document Number: 1724000887-QC-LIS-00012

Document Class: 2

03	06/12/2024	Accepted for Construction (AFC)	SB	RV	ADL
02	31/10/2024	Accepted for Construction (AFC)	SB	RV	ADL
01	25/10/2024	Accepted for Construction (AFC)	SB	RV	ADL
00	19/09/2024	Issue for Review (IFR)	SB	RV	ADL
Rev.	Date	Description	Prepared	Reviewed	Approved

THERMO ENGINEERING AN ENCORE COMBUSTION COMPANY

THERMO ENGINEERING® ADVANCED COMBUSTION SYSTEMS

This document undergoes an issuance cycle within EDMS "Fusionlive".
Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Table of Contents

SH.	DESCRIPTION	REVISIONS							
		00	01	02	03				
1	Cover	X	X	X	X				
2	Table of Contents	X	X	X	X				
3	Revision / Change Log	X	x	X	X				
4	Atex Register	x	x	X	X				

This document undergoes an issuance cycle within EDMS "Fusionlive".
Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Revision / Change Log

Rev.	Description
00	ISSUE FOR REVIEW (IFR)
01	ACCEPTED FOR CONSTRUCTION (AFC)
02	ACCEPTED FOR CONSTRUCTION (AFC)
03	ACCEPTED FOR CONSTRUCTION (AFC)

HOLDS LIST

No.	Description
1.	
2.	
3.	
4.	

No.	Revision	Tag Number	Description	Location	Manufacturer	Model Type Catalogue Number	Serial Number	ATEX Certification Marking	Reference Document	ATEX Certificate Number	Installation Zone	Notes / Comments	P.O.	Vendor	Skid / Package	Barrier Calculation Ref.	Non-Electrical Equipment	Special Conditions of safe use Applicable
1	00	H-ETE-200N1-19-L3-01	Raychem Self-Regulating Heating Cable	Hydrogen Vent	nVent Thermal CC	XTVR2-CT	NA	II 2 GD Ex 60079-30-1 eb IIC T* Gb / Ex 60079-30-1 tb IIIC T**°C Db	1724000887-MAC-DG-00007	XTVR_SGS20ATEX0049X_Iss. 4 1	Zone 2	NA	1724000887	Encore Thermoengineer ing SRL	Hydrogen Vent	NA	NO	YES
2	00	ETB-200N1-19-L3-01	Thermostat V407	Hydrogen Vent	nVent Thermal Belgium NV	ETS-05	5020019	II 2(1)G Ex eb ia mb [ia Ga] IIC T5 Gb -40°C ≤ Ta ≤ +60°C II 2D Ex tb IIIC T100°C Db	1724000887-MAC-DG-00007	ETS-05_Baseefa13ATEX0137 Issue 6	Zone 2	NA	1724000887	Encore Thermoengineer ing SRL	Hydrogen Vent	NA	NO	NO

*Note: ETE confirms that all the Atex equipment are identified in the above table

**Note: refer to Doc. No. 1724000887-MAC-LIS-00013 - Atex Certificate" for certifications