Base Load Power Hub (BLPH)

SHIPPING AND HANDLING PROCEDURE – EHT

ROSETTI MARINO	
1	APPROVED - WORK MAY PROCEED
2N	REVISE AND RE-SUBMIT - DO NOT PROCEED
2Y	REVISE AND RE-SUBMIT - WORK MAY PROCEED
3	REJECTED
4	APPROVAL NOT REQUIRED

NOTE: Approval doesn't relieve the supplier from mandatory compliance with contractual documents and specifications. Comments made do not imply acceptance of any cost or delivery impact.

Sign	Date
	27/09/2024

Document Number:
1724001647-QC-PRO-00016

Document Class: 3

00	26/09/2024	Issue for Information (IFI)	L. Gentile	A. Martelli	P. Padovani
Rev.	Date	Description	Prepared	Reviewed	Approved

nVent

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Revision / Change Log

Rev.	Description
00	Issue for Information (IFI)

HOLDS LIST

No.	Description
1	
2	
3	
4	

TABLE OF CONTENTS

1. Special precautions for handling and transport..... 4

2. Recommendations for storage.....5

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

1 SPECIAL PRECAUTIONS FOR HANDLING AND TRANSPORT

Self regulating heaters

During all storage, transport and handling, crates must be kept in the upright position as shown on the crates.

All heater strip and associated components should be kept sealed in their packing and stored in a dry, preferably heated environment.

All packing should be visually inspected every 6 months for physical damage.

Materials should not be released to the field until they are needed for construction, so as to minimise inadvertent damage.

All self-regulating accessories must be kept in their individual plastic bags until installation.

Handling of the reels must be done manually.

When unpacking the components, cables and other materials included in the electric heat tracing system, a general inspection should be conducted including confirmation of the correct type and quantities of material and corresponding documentation.

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

2 RECOMMENDATIONS FOR STORAGE

The storage system must be defined to avoid risks following mechanical, physical or atmospheric damages. Store all materials in a clean and dry place. The ground must be flat and without humidity.

Temperature range :

Self regulating heaters - 40°C/+ 60°C