Ballard Power Systems Europe A/S
Majsmarken 1
9500 Hobro
Denmark

Revision history		
Rev.	**Date.**	**Description**
001	30/05/2023	First Issue
002	11/08/2023	Expanded, completed list

Document Title:	**BLPH Project - Piping Line List and Speciality Item List**
Document Number:	K559-2254-CWIWP4202202-C05-001
Revision:	Rev001
Sequence Number:	001
File Name:	K559-2254-CWIWP4202202-C05-001Rev001
Purchaser Job:	K559-2254
Purchase Order:	CWIWP4202202
Code:	C05
Requsition Number:	n/a
Customer:	CrossWind C.V., Rotterdam, The Netherlands

Piping Class Overivew and Piping Line List

Crosswind/Shell Baseload Power Hub, Fuel Cell Container 1MW, no BESS

Table of Contents

Higher-Level Function	Mounting Location	Page	Page Description	Last Modified Date
		1	Document C05 Introduction	11-Aug-23
		2	Pre-planning: Pipe class overview : CustomerScope - RadiaCord-122	11-Aug-23
		3	P&I diagram: Piping overview : Hydrogen - Hydrogen	02-Jun-23
		4	P&I diagram: Piping overview : Water - Water	11-Aug-23
		5	P&I diagram: Piping overview : Ventilation - ProcessExhaust	11-Aug-23
		6	P&I diagram: Piping overview : HT_Coolant - HT_Coolant	11-Aug-23

Reference Item Number	Ballard Part # TBD		
EPLAN Project Name	601456B - Shell Baseload Power Hub		
EPLAN Revision	--.P11		
EPLAN Project Pages	53		
=	++	+	& D01

REVISION INFORMATION
DESCRIPTION
CO???????
DATE
11-Aug-23

THIS DOCUMENT, SUBMITTED IN CONFIDENCE, CONTAINS PROPRIETARY INFORMATION WHICH SHALL NOT BE REPRODUCED OR TRANSFERRED TO OTHER DOCUMENTS OR DISCLOSED TO OTHERS OR USED FOR MANUFACTURING OR ANY OTHER PURPOSE WITHOUT PRIOR WRITTEN PERMISSION OF BALLARD POWER SYSTEMS INC. OR A RELATED WHOLLY-OWNED SUBSIDIARY OR AFFILIATE.

BALLARD™
COMMERCIAL CONFIDENTIAL

THIS DOCUMENT'S APPROVAL IS MANAGED BY E-SIGNATURE ON FILE IN BALLARD POWER SYSTEMS' PLM SYSTEM

DRAWING	601456B-C05	REVISION	--.P11
DRAWING TITLE	EPLAN P8 Project, ???????		
SHEET TYPE/DESC	Document C05 Introduction		
ALL SHEETS ARE THE SAME REVISION STATUS	SIZE A3	LANGUAGE EN	SHEET/TOTAL 1 / 3

Pre-planning: Pipe class overview

F49_001

	Pipe class	Description	Standard	Nominal pressure level	Material
1	CustomerScope	Piping is within Customer Scope	Customer Scope	Customer Scope	AISI 316 Suggested
2	DN25-PIPE	Seamless hydraulic pipe, acid-resistant	EN 10216-5, ASTM A269/A213	166 bar dynamic, 194 static (DIN2421)	AISI 316
3	DN32-PIPE	Seamless hydraulic pipe, acid-resistant	EN 10216-5, ASTM A269/A213	166 bar dynamic, 194 static (DIN2421)	AISI 316
4	DN50-PIPE	Stainless Steel Pipe, 2mm wall thickness	EN 10216-5	2mm pipe wall thickness	AISI 304
5	DN50x1.6	60,3 x 1,6mm Pipe, Material 1.4404	EN 1092-1	n/a	1.4404 (X2XrNiMo17-12-2)
6	DN80x2.0	88.9 x 2.0 mm Pipe, Material 1.4404	EN 1092-1	n/a	1.4404 (X2XrNiMo17-12-2)
7	RadiaCord-122	Ø 122mm x 6,0mm, Flexible Coolant Hose	DIN 73411	4bar	EPDM

THIS DOCUMENT, SUBMITTED IN CONFIDENCE, CONTAINS PROPRIETARY INFORMATION WHICH SHALL NOT BE REPRODUCED OR TRANSFERRED TO OTHER DOCUMENTS OR DISCLOSED TO OTHERS OR USED FOR MANUFACTURING OR ANY OTHER PURPOSE WITHOUT PRIOR WRITTEN PERMISSION OF BALLARD POWER SYSTEMS INC. OR A RELATED WHOLLY-OWNED SUBSIDIARY OR AFFILIATE.

BALLARD™
COMMERCIAL CONFIDENTIAL

THIS DOCUMENT'S APPROVAL IS MANAGED BY E-SIGNATURE ON FILE IN BALLARD POWER SYSTEMS' PLM SYSTEM

P&I diagram: Piping overview

F37_001-BPSE

Piping Name	From (Source)	To (Target)	Pipe Class	Length	Substance (Contents)	Pressure	Flow	Temperature	
-HKN70_H2	=HKN70-C01	=HA01+DA02-XM01	CustomerScope		Hydrogen	3,5 - 6,5 barg	0,9 - 29,4 g/s	-8,4 - 80°C	
-WP_H2900	=HA01+DA02-XM01	=HA01+DA02-QM00	DN32-PIPE		Hydrogen	3,5 - 6,5 barg	0,9 - 29,4 g/s	-8,4 - 80°C	
-WP_H2901	=HA01+DA02-QM04	=HA01+DA02-QM00	DN32-PIPE		Hydrogen	3,5 - 6,5 barg	0,9 - 29,4 g/s	-8,4 - 80°C	
-WP_H2902	=HA01+DA02-QM16	=HA01+DA02-QM26	DN25-PIPE	220 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2903	=HA01+DA02-QM15	=HA01+DA02-QM25	DN25-PIPE	220 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2904	=HA01+DA02-QM14	=HA01+DA02-QM24	DN25-PIPE	220 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2905	=HA01+DA02-QM13	=HA01+DA02-QM23	DN25-PIPE	220 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2906	=HA01+DA02-QM12	=HA01+DA02-QM22	DN25-PIPE	220 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2907	=HA01+DA02-QM11	=HA01+DA02-QM21	DN25-PIPE	220 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2912	=HA01+DA02-QM26	=HA01+DA02-XT06	DN25-PIPE	5477 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2913	=HA01+DA02-QM25	=HA01+DA02-XT05	DN25-PIPE	4390 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2914	=HA01+DA02-QM24	=HA01+DA02-XT04	DN25-PIPE	3303 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2915	=HA01+DA02-QM23	=HA01+DA02-XT03	DN25-PIPE	3462 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2916	=HA01+DA02-QM22	=HA01+DA02-XT02	DN25-PIPE	4547 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2917	=HA01+DA02-QM21	=HA01+DA02-XT01	DN25-PIPE	5637 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2922	=HA01+DA02-XT06	=RE02+GB06-XM01	DN25-PIPE	5477 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2923	=HA01+DA02-XT05	=RE02+GB05-XM01	DN25-PIPE	4390 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2924	=HA01+DA02-XT04	=RE02+GB04-XM01	DN25-PIPE	3303 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2925	=HA01+DA02-XT03	=RE01+GB03-XM01	DN25-PIPE	3462 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2926	=HA01+DA02-XT02	=RE01+GB02-XM01	DN25-PIPE	4547 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2927	=HA01+DA02-XT01	=RE01+GB01-XM01	DN25-PIPE	5637 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2942	=HA01+DA02-QM16	=HA01+DA02-QM06	DN25-PIPE	190 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2943	=HA01+DA02-QM15	=HA01+DA02-QM05	DN25-PIPE	190 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2944	=HA01+DA02-QM14	=HA01+DA02-QM04	DN25-PIPE	190 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2945	=HA01+DA02-QM13	=HA01+DA02-QM03	DN25-PIPE	190 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2946	=HA01+DA02-QM12	=HA01+DA02-QM02	DN25-PIPE	190 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	
-WP_H2947	=HA01+DA02-QM01	=HA01+DA02-QM11	DN25-PIPE	190 mm	Hydrogen	3,5-6,5 barg	<4,9 g/s	-8,4 - 80°C	

Reference Item Number	Ballard Part # TBD
EPLAN Project Name	601456B - Shell Baseload Power Hub
EPLAN Revision	--.P11
EPLAN Project Pages	53
=	++ | + | & D01

REVISION INFORMATION
DESCRIPTION
DATE
11-Aug-23

THIS DOCUMENT, SUBMITTED IN CONFIDENCE, CONTAINS PROPRIETARY INFORMATION WHICH SHALL NOT BE REPRODUCED OR TRANSFERRED TO OTHER DOCUMENTS OR DISCLOSED TO OTHERS OR USED FOR MANUFACTURING OR ANY OTHER PURPOSE WITHOUT PRIOR WRITTEN PERMISSION OF BALLARD POWER SYSTEMS INC. OR A RELATED WHOLLY-OWNED SUBSIDIARY OR AFFILIATE.

BALLARD™ COMMERCIAL CONFIDENTIAL

THIS DOCUMENT'S APPROVAL IS MANAGED BY E-SIGNATURE ON FILE IN BALLARD POWER SYSTEMS' PLM SYSTEM

DRAWING	601456B-C05	REVISION	--.P11
DRAWING TITLE			
SHEET TYPE/DESC	P&I diagram: Piping overview : Hydrogen - Hydrogen		
ALL SHEETS ARE THE SAME REVISION STATUS	SIZE A3	LANGUAGE EN	SHEET/TOTAL 3 / 3

P&I diagram: Piping overview

F37_001-BPSE

Piping Name	From (Source)	To (Target)	Pipe Class	Length	Substance (Contents)	Pressure	Flow	Temperature	
	+DA01-X10	=HKN70-XM02			Water		<13,2 l/min	10-50°C	
	=JB01+DA01-CL01				Water		<6,6 l/min	10-50°C	
	=JB01+DA01-CL01				Water		<6,6 l/min	10-50°C	
	=JB01+DA01-CL01	=HKN70-XM02	DN50-PIPE		Water		<13,2 l/min	10-50°C	
	=HE01+DA02-CL01	=JB01+DA01-CL01			Water			Ambient Temp	
	=HE02+DA02-CL01	=JB01+DA01-CL01			Water			Ambient Temp	
	=HE03+DA03-CL01	=JB01+DA01-CL01			Water			Ambient Temp	

Reference Item Number	Ballard Part # TBD		
EPLAN Project Name	601456B - Shell Baseload Power Hub		
EPLAN Revision	--.P11		
EPLAN Project Pages	53		
=	++	+	& D01

REVISION INFORMATION
DESCRIPTION
DATE
11-Aug-23

THIS DOCUMENT, SUBMITTED IN CONFIDENCE, CONTAINS PROPRIETARY INFORMATION WHICH SHALL NOT BE REPRODUCED OR TRANSFERRED TO OTHER DOCUMENTS OR DISCLOSED TO OTHERS OR USED FOR MANUFACTURING OR ANY OTHER PURPOSE WITHOUT PRIOR WRITTEN PERMISSION OF BALLARD POWER SYSTEMS INC. OR A RELATED WHOLLY-OWNED SUBSIDIARY OR AFFILIATE.

BALLARD™
COMMERCIAL CONFIDENTIAL

THIS DOCUMENT'S APPROVAL IS MANAGED BY E-SIGNATURE ON FILE IN BALLARD POWER SYSTEMS' PLM SYSTEM

DRAWING	601456B-C05	REVISION	--.P11
DRAWING TITLE			
SHEET TYPE/DESC	P&I diagram: Piping overview : Water - Water		
ALL SHEETS ARE THE SAME REVISION STATUS	SIZE A3	LANGUAGE EN	SHEET/TOTAL 4 /

P&I diagram: Piping overview

F37_001-BPSE

Piping Name	From (Source)	To (Target)	Pipe Class	Length	Substance (Contents)	Pressure	Flow	Temperature	
-WP_A2010	=JA02+DA02-WM07		DN50x1.6		Ventilation	<50mbarg	120 Nm³/h	5-45°C	
-WP_A2011	=JA02+DA02-WM08		DN50x1.6		Ventilation	<50mbarg	120 Nm³/h	5-45°C	
-WP_A2012	=JA02+DA02-WM09		DN50x1.6		Ventilation	<50mbarg	120 Nm³/h	5-45°C	
-WP_A2013	=JA02+DA02-WM10		DN50x1.6		Ventilation	<50mbarg	120 Nm³/h	5-45°C	
-WP_A2014		=JA02+DA02-WM11	DN50x1.6		Ventilation	<50mbarg	120 Nm³/h	5-45°C	
-WP_A2015	=JA02+DA02-WM12		DN50x1.6		Ventilation	<50mbarg	120 Nm³/h	5-45°C	
-WP_A2020	=JA02+DA02-WM01		DN80x2.0		ProcessExhaust	<50mbarg	650 Nm³/h	50-80°C	
-WP_A2021	=JA02+DA02-WM02		DN80x2.0		ProcessExhaust	<50mbarg	650 Nm³/h	50-80°C	
-WP_A2022	=JA02+DA02-WM03		DN80x2.0		ProcessExhaust	<50mbarg	650 Nm³/h	50-80°C	
-WP_A2023		=JA02+DA02-WM04	DN80x2.0		ProcessExhaust	<50mbarg	650 Nm³/h	50-80°C	
-WP_A2024	=JA02+DA02-WM05		DN80x2.0		ProcessExhaust	<50mbarg	650 Nm³/h	50-80°C	
-WP_A2025		=JA02+DA02-WM06	DN80x2.0		ProcessExhaust	<50mbarg	650 Nm³/h	50-80°C	

Reference Item Number	Ballard Part # TBD		
EPLAN Project Name	601456B - Shell Baseload Power Hub		
EPLAN Revision	--.P11		
EPLAN Project Pages	53		
=	++	+	& D01

REVISION INFORMATION
DESCRIPTION
DATE
11-Aug-23

THIS DOCUMENT, SUBMITTED IN CONFIDENCE, CONTAINS PROPRIETARY INFORMATION WHICH SHALL NOT BE REPRODUCED OR TRANSFERRED TO OTHER DOCUMENTS OR DISCLOSED TO OTHERS OR USED FOR MANUFACTURING OR ANY OTHER PURPOSE WITHOUT PRIOR WRITTEN PERMISSION OF BALLARD POWER SYSTEMS INC. OR A RELATED WHOLLY-OWNED SUBSIDIARY OR AFFILIATE.

BALLARD™ COMMERCIAL CONFIDENTIAL

THIS DOCUMENT'S APPROVAL IS MANAGED BY E-SIGNATURE ON FILE IN BALLARD POWER SYSTEMS' PLM SYSTEM

DRAWING	601456B-C05	REVISION	--.P11
DRAWING TITLE			
SHEET TYPE/DESC	P&I diagram: Piping overview : Ventilation - ProcessExhaust		
ALL SHEETS ARE THE SAME REVISION STATUS	SIZE A3	LANGUAGE EN	SHEET/TOTAL 5 /

P&I diagram: Piping overview

F37_001-BPSE

Piping Name	From (Source)	To (Target)	Pipe Class	Length	Substance (Contents)	Pressure	Flow	Temperature	
-WP_C101		=HE01+DA02-EG01	RadiaCord-122		HT_Coolant		<100 m³/h	40-55 °C	
-WP_C102		=HE02+DA02-EG01	RadiaCord-122		HT_Coolant		<100 m³/h	40-55 °C	
-WP_C201		=HE01+DA02-EG01	RadiaCord-122		HT_Coolant		<100 m³/h	10-40 °C	
-WP_C202		=HE02+DA02-EG01	RadiaCord-122		HT_Coolant		<100 m³/h	10-40 °C	

Reference Item Number	Ballard Part # TBD		
EPLAN Project Name	601456B - Shell Baseload Power Hub		
EPLAN Revision	--.P11		
EPLAN Project Pages	53		
=	++	+	& D01

REVISION INFORMATION
DESCRIPTION
DATE
11-Aug-23

THIS DOCUMENT, SUBMITTED IN CONFIDENCE, CONTAINS PROPRIETARY INFORMATION WHICH SHALL NOT BE REPRODUCED OR TRANSFERRED TO OTHER DOCUMENTS OR DISCLOSED TO OTHERS OR USED FOR MANUFACTURING OR ANY OTHER PURPOSE WITHOUT PRIOR WRITTEN PERMISSION OF BALLARD POWER SYSTEMS INC. OR A RELATED WHOLLY-OWNED SUBSIDIARY OR AFFILIATE.

BALLARD™
COMMERCIAL CONFIDENTIAL

THIS DOCUMENT'S APPROVAL IS MANAGED BY E-SIGNATURE ON FILE IN BALLARD POWER SYSTEMS' PLM SYSTEM

DRAWING	601456B-C05	REVISION	--.P11
DRAWING TITLE			
SHEET TYPE/DESC	P&I diagram: Piping overview : HT_Coolant - HT_Coolant		
ALL SHEETS ARE THE SAME REVISION STATUS	SIZE A3	LANGUAGE EN	SHEET/TOTAL 6 /