Ballard Power Systems Europe A/S
Majsmarken 1
9500 Hobro
Denmark

Revision history		
Rev.	**Date.**	**Description**
001	13/10/2023	First Issue

Document Title:	**BLPH Project - Ingress Protection Certificates**
Document Number:	K559-2254-CWIWP4202202-K11-001
Revision:	Rev001
Sequence Number:	001
File Name:	K559-2254-CWIWP4202202-K11-001Rev001
Purchaser Job:	K559-2254
Purchase Order:	CWIWP4202202
Code:	K11
Requsition Number:	n/a
Customer:	CrossWind C.V., Rotterdam, The Netherlands

TEST REPORT

IP44 test of FCwave 200 kW power cabinet

Ballard Power Systems Europe A/S

Report no.: 122-22396-1

1 appendix

TEST Reg. no. 19

4 Test and results

4.1 Test summary

The following tests were carried out as agreed with the client.

Test name	Standard	Test object
IP 4X (Protected against solid foreign objects of 1,0 mm and greater)	IEC 60529	**OK**
IP X4 (Protected against splashing water)	IEC 60529	**OK**