DRAWING NO. DRAWING_NO.

REV. REV

A-50000
WATER TREATMENT PACKAGE
CAPACITY : 2.5 m³/hr

GAS CONFIRMED 50 XA 001 — F&G
SMOKE CONFIRMED 50 XA 002 — F&G
FAULT PACKAGE 50 XA 003 — ESD
50-XS-001 SHUT-DOWN — ESD
NOTE 6

CONTRACTOR | SUPPLIER

123A90-DDL-PR-PID-80025
TO 50-TDI-002
50 TI 001
BLOCKED OUTLET SET @ 6 barg
50 PSV 011 1D2
2"-SWR-291-01SD-N
50 TT 001
50 TE 001
03
BLPH-MV-471
SD LO
NOTE 7
1"-SWS-290-01SD-E
1.1/2"
TP 017 50
E
4"x1.1/2"
4"x1.1/2"
123A90-DDL-PR-PID-80021
FROM SEA WATER LIFT PUMP
1-1/2"-SWS-035-01SD-E
ECC. RED.
ECC. RED.
BLPH-MV-241
3/4"

FOR CONTINUATION SEE DOC N. 123A90-DDL-PR-PID-80023

A-50000
WATER TREATMENT PACKAGE
SEE VENDOR DRAWING
DOC. N. 1724000448-PR-PID-00013

FOR CONTINUATION SEE DOC N. 123A90-DDL-PR-PID-80023

E
TP 005 50 03
123A90-DDL-PR-PID-80021
TO SEA WATER LIFT PUMP AND LIFT PUMP CAISSONS
1"-CI-029-01CP-E

1"-CI-043-01CP-E
TP 006 50 03
DECK
HOOK-UP 003
123A90-DDL-PR-PID-80026
TO WASTE WATER TANK

SUPPLIER | CONTRACTOR

TP 003 50 03
1.1/2"x1"
3"x1.1/2"
1"-SWR-045-01CS-H
123A90-DDL-PR-PID-80025
TO BRINE DISCHARGE CAISSON

TP 007 50 03
1.1/2"x1"
1"-WW-038-01CS-H
123A90-DDL-PR-PID-80026
TO WASTE WATER TANK

NOTES

1. DELETED.
2. DELETED.
3. DELETED.
4. DELETED.
5. DELETED.
6. SERIAL COMMUNICATION WITH CONTROL SYSTEM.
7. ROUTED TO THE SEA. 03

HOLDS

1. DELETED.
2. DELETED.
3. DELETED.
4. DELETED.
5. DELETED.
6. DELETED.

REV.	DATE	DRN	CHKD	APPD	DESCRIPTION
03	09/09/2024	CIM	RZI	DLO	ACCEPTED FOR CONSTRUCTION (AFC)
02	12/06/2024	CIM	RZI	DLO	ACCEPTED FOR CONSTRUCTION (AFC)
01	15/02/2024	CIM	RZI	DLO	ISSUE FOR ACCEPTANCE (IFA)
00	20/10/2023	CIM	RZI	DLO	ISSUE FOR ACCEPTANCE (IFA)

CROSSWIND

ROSETTI MARINO

TITLE :
BLPH PIPING AND INSTRUMENTATION DIAGRAM
SEA-WATER INTAKE SYSTEM SHEET 2

CONTRACT NO./TITLE	CW-I-WP4-2023-05/HOLLANDSE KUST NOORD WIND PARK	SCALE	NTS
DRAWN	CHECKED	APPROVED	DATE

A1	DRAWING NO. 123A90-DDL-PR-PID-80022	SHEET 001	REV. 03

File Name : FILE_NAME