Base Load Power Hub (BLPH)

INSTRUMENT AIR PACKAGE
INSTRUMENT LIST
WITH SET POINTS / CONTROL / ALARM / SHUTDOWN

Document Number: 1724000428-IN-LIS-00017

Document Class: 2

Rev.	Date	Description	Prepared	Reviewed	Approved
06	09/05/2025	Accepted for Construction (AFC)	GT	MC	TM
05	01/04/2025	Accepted for Construction (AFC)	GT	MC	TM
04	16/12/2024	Accepted for Construction (AFC)	GT	MC	TM
03	03/09/2024	Issue for Review (IFR)	GT	MC	TM
02	04/07/2024	Issue for Review (IFR)	GT	MC	TM
01	20/05/2024	Issue for Review (IFR)	GT	MC	TM
00	19/04/2024	Issue for Review (IFR)	GT	MC	TM

COES

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Item	TAG	SERVICE	SIGNAL	RANGE	SET POINT	NOTES
Pressure transmitter	63-PIT-064	Instrument Air Receiver pressure	4-20mA	0 / 16 barg	7 bar	L ALARM
Differential pressure transmitter	63-PDIT-051	Pre-filter pressure drop	4-20mA	0 / 1 bar	0.5 bar	H ALARM
Differential pressure transmitter	63-PDIT-062	Post-filter pressure drop	4-20mA	0 / 1 bar	0.5 bar	H ALARM
Pressure gauge	63-PI-053 63-PI-055 63-PI-057 63-PI-059	Air dryer towers pressure	N/A	0 / 16 barg	N/A	
Pressure gauge	63-PI-063	Instrument Air Receiver pressure	N/A	0 / 16 barg	N/A	
Differential pressure gauge	63-PDI-052 63-PDI-061	Air dryer pressure drop	N/A	0 / 2.5 bar	N/A	
Pressure switch	63-PS-054 63-PS-056 63-PS-058 63-PS-060	Air dryer towers pressure	SPST	0 / 12 barg	5 barg	L ALARM
Temperature transmitter	63-TIT-051	Air dryer inlet temperature	4-20mA	0 / 100°C	40°C	H ALARM
Temperature transmitter	63-TIT-052	Instrument Air Receiver temperature	4-20mA	0 / 100°C	40°C	H ALARM

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Item	TAG	SERVICE	SIGNAL	RANGE	SET POINT	NOTES
Temperature gauge	63-TI-053	Instrument Air Receiver temperature	N/A	0 / 100°C	N/A	
Dew point analyzer	63-AIT-051	Outlet dew point	4-20mA	-100 / +20°C	-40°C	H ALARM
Flow transmitter	63-FIT-051	Outlet flowrate	4-20mA	0 / 500 Sm3/h	N/A	MONITORING
Solenoid Valve	63-XY-051 63-XY-052 63-XY-053 63-XY-054 63-XY-055 63-XY-056 63-XY-057 63-XY-058 63-XY-059 63-XY-060	Pneumatic on-off valves actuation	24 VDC	0 / 9 barg	N/A	N/A
Pneumatic on-off valve	63-XV-051 63-XV-052 63-XV-053 63-XV-054	Dryer towers change-over	N/A	0 / 9 barg	N/A	N/A
Pneumatic on-off valve	63-XV-055 63-XV-056	Pre-filters change-over	N/A	0 / 9 barg	N/A	N/A
Pneumatic on-off valve	63-XV-057 63-XV-058	Air Dryer change-over	N/A	0 / 9 barg	N/A	N/A
Pneumatic on-off valve	63-XV-059 63-XV-060	Post-filters change-over	N/A	0 / 9 barg	N/A	N/A

This document undergoes an issuance cycle within EDMS Fusionlive". Its distribution is electronically controlled. Once printed shall be considered as "NOT CONTROLLED" copy

Pressure Safety valves	63-PSV-001 63-PSV-002 63-PSV-003 63-PSV-004 63-PSV-005	Overpressure protection	N/A	N/A	12 barg	N/A
Flow orifice	63-FO-001 63-FO-002	Purge flowrate	N/A	N/A	N/A	4 mm bore diameter
Flow transmitter orifice	63-FO-051	Outlet flow	N/A	N/A	N/A	31.2 mm bore diameter

Reference document:

P&ID, document no. 1724000428-PR-PID-00019 Sheet 1 of 2. Sheet 2 of 2 is the air compressor's P&ID which is considered a single standard components: details of the installed instruments are not available.