DRAWING NO. DRAWING_NO. 123A90-DDL-PR-PID-80022

REV. REV 04

A-50000

WATER TREATMENT PACKAGE

CAPACITY : 2.5 m³/hr

GAS CONFIRMED 50 XA 001 — F&G

SMOKE CONFIRMED 50 XA 002 — F&G

FAULT PACKAGE 50 XA 003 — ESD

50-XS-001 SHUT-DOWN — ESD

NOTE 6

CONTRACTOR | SUPPLIER

FOR CONTINUATION SEE DOC N. 123A90-DDL-PR-PID-80023

123A90-DDL-PR-PID-80025
TO 50-TDI-002

50 TI 001

[Description]
BLOCKED OUTLET
SET @ 6 barg

50 PSV 011 1D2

2"-SWR-291-01SD-N

50 TT 001

50 TE 001

BLPH-MV-471 LS LO

[NAN]

NOTE 7

1"-SWS-290-01SD-E

1.1/2"

TP 017 50

E

4"x1.1/2" ECC. RED.

4"x1.1/2" ECC. RED.

123A90-DDL-PR-PID-80021
FROM SEA WATER LIFT PUMP

1-1/2"-SWS-035-01SD-E

BLPH-MV-241 3/4"

A-50000

WATER TREATMENT PACKAGE

SEE VENDOR DRAWING

DOC. N. 1724000448-PR-PID-00013

FOR CONTINUATION SEE DOC N. 123A90-DDL-PR-PID-80023

E

TP 005 50

123A90-DDL-PR-PID-80021
TO SEA WATER LIFT PUMP AND LIFT PUMP CAISSONS

1"-CI-029-01CP-E

1"-CI-043-01CP-E

TP 006 50

123A90-DDL-PR-PID-80026
TO WASTE WATER TANK

DECK HOOK-UP 003

SUPPLIER | CONTRACTOR

TP 003 50

1.1/2"x1"

3"x1.1/2"

1"-SWR-045-01CS-H

123A90-DDL-PR-PID-80025
TO BRINE DISCHARGE CAISSON

TP 007 50

1.1/2"x1"

[NAN]

1"-WW-038-01CS-H

123A90-DDL-PR-PID-80026
TO WASTE WATER TANK

NOTES

1. DELETED.
2. DELETED.
3. DELETED.
4. DELETED.
5. DELETED.
6. SERIAL COMMUNICATION WITH CONTROL SYSTEM.
7. ROUTED TO THE SEA.

HOLDS

1. DELETED.
2. DELETED.
3. DELETED.
4. DELETED.
5. DELETED.
6. DELETED.

REV.	DATE	DRN	CHKD	APPD	DESCRIPTION
04	21/10/2025	RZI	RZI	CGI	AS BUILT
03	09/09/2024	CIM	RZI	DLO	ACCEPTED FOR CONSTRUCTION (AFC)
02	12/06/2024	CIM	RZI	DLO	ACCEPTED FOR CONSTRUCTION (AFC)
01	15/02/2024	CIM	RZI	DLO	ISSUE FOR ACCEPTANCE (IFA)
00	20/10/2023	CIM	RZI	DLO	ISSUE FOR ACCEPTANCE (IFA)

CROSSWIND

ROSETTI MARINO

TITLE :

BLPH PIPING AND INSTRUMENTATION DIAGRAM
SEA-WATER INTAKE SYSTEM SHEET 2

CONTRACT NO./TITLE	CW-I-WP4-2023-05/HOLLANDSE KUST NOORD WIND PARK	SCALE	NTS
DRAWN	CHECKED	APPROVED	DATE

A1	DRAWING NO. 123A90-DDL-PR-PID-80022	SHEET 001	REV. 04

File Name : FILE_NAME