DRAWING NO. DRAWING_NO.123A90-DDL-PR-PID-80024

REV. REV04

A-50000
WATER TREATMENT PACKAGE
CAPACITY : 2.5 m³/hr

FOR CONTINUATION SEE DOC N.
123A90-DDL-PR-PID-80023

SUPPLIER CONTRACTOR

A-50000
WATER TREATMENT PACKAGE
SEE VENDOR DRAWING
DOC. N. 1724000448-PR-PID-00013

1"-DM-001-01SS-E-1 → 123A90-DDL-PR-PID-80011
TO ELECTROLYSER PACKAGE

TP 007 50

NOTE 8

FOR CONTINUATION SEE DOC N.
123A90-DDL-PR-PID-80023

NOTES

1. DELETED.
2. DELETED.
3. DELETED.
4. DELETED.
5. DELETED.
6. DELETED.
7. DELETED.
8. PH, TEMPERATURE, HARDNESS AND CONDUCTIVITY SHALL BE SENT FROM WATER TREATMENT UCP TO CONTROL SYSTEM IN ADDITION TO THE OTHER SOFTWARE SIGNALS.

HOLDS

1. DELETED.
2. DELETED.
3. DELETED.
4. DELETED.
5. DELETED.

REV.	DATE	DRN	CHKD	APPD	DESCRIPTION
04	21/10/2025	RZI	RZI	CGI	AS BUILT
03	09/09/2024	CIM	RZI	DLO	ACCEPTED FOR CONSTRUCTION (AFC)
02	12/06/2024	CIM	RZI	DLO	ACCEPTED FOR CONSTRUCTION (AFC)
01	15/02/2024	CIM	RZI	DLO	ISSUE FOR ACCEPTANCE (IFA)
00	20/10/2023	CIM	RZI	DLO	ISSUE FOR ACCEPTANCE (IFA)

CROSSWIND

ROSETTI MARINO

TITLE :
BLPH PIPING AND INSTRUMENTATION DIAGRAM
WATER TREATMENT PLANT SHEET 2

06 21/10/2025 RZI RZI CGI AS BUI

CONTRACT NO./TITLE	CW-I-WP4-2023-05/HOLLANDSE KUST NOORD WIND PARK	SCALE	NTS
DRAWN	CHECKED	APPROVED	DATE

A1	DRAWING NO. 123A90-DDL-PR-PID-80024	SHEET 001	REV. 04

File Name : FILE_NAME