DRAWING NO. DRAWING_NO.

REV. REV

FOR CONTINUATION SEE DOC N.
123A90-DDL-PR-PID-80023

A-50000
WATER TREATMENT PACKAGE
CAPACITY : 2.5 m³/hr

SUPPLIER | CONTRACTOR

A-50000
WATER TREATMENT PACKAGE
SEE VENDOR DRAWING
DOC. N. 1724000448-PR-PID-00013

1"-DM-001-01SS-E-1 → 123A90-DDL-PR-PID-80011

1"-DM-001-01SS-E-1 → 123A90-DDL-PR-PID-80011
TO ELECTROLYSER PACKAGE

TP 002 50 03

PH
TEMPERATURE
HARDNESS
CONDUCIVITY
NOTE 8

FOR CONTINUATION SEE DOC N.
123A90-DDL-PR-PID-80023

NOTES

1. DELETED.
2. DELETED.
3. DELETED.
4. DELETED.
5. DELETED.
6. DELETED.
7. DELETED.
8. PH, TEMPERATURE, HARDNESS AND CONDUCTIVITY SHALL BE SENT FROM WATER TREATMENT UCP TO CONTROL SYSTEM IN ADDITION TO THE OTHER SOFTWARE SIGNALS.

HOLDS

1. DELETED.
2. DELETED.
3. DELETED.
4. DELETED.
5. DELETED.

REV.	DATE	DRN	CHKD	APPD	DESCRIPTION
03	09/09/2024	CIM	RZI	DLO	ACCEPTED FOR CONSTRUCTION (AFC)
02	12/06/2024	CIM	RZI	DLO	ACCEPTED FOR CONSTRUCTION (AFC)
01	15/02/2024	CIM	RZI	DLO	ISSUE FOR ACCEPTANCE (IFA)
00	20/10/2023	CIM	RZI	DLO	ISSUE FOR ACCEPTANCE (IFA)

CROSSWIND

ROSETTI MARINO

TITLE :
BLPH PIPING AND INSTRUMENTATION DIAGRAM
WATER TREATMENT PLANT SHEET 2

CONTRACT NO./TITLE	CW-I-WP4-2023-05/HOLLANDSE KUST NOORD WIND PARK	SCALE	NTS
DRAWN	CHECKED	APPROVED	DATE

A1	DRAWING NO.	SHEET	REV.
	123A90-DDL-PR-PID-80024	001	03

File Name : FILE_NAME