HSE Walkdown Checklist - Safe access to BLPH

1) Lower Deck Tech. Rooms

#	Item	Check	Comments / Actions Reqired
1.	Walkways and access routes are clear and unobstructed	☑	
2.	No open edge, no risk of falling from height	☑	
3.	No risk of dropped objects	☑	
4.	No loose items	☑	
5.	Safety signages in place	☑	
6.	Container doors closed	☑	BESS Keys handed over to CW
7.	Cables and wires are organized	☑	
8.	Safety cabinets in place and not damaged	☑	
9.	No signs of chemical or oil spills	☑	
10.	Vertical ladders are secure and usable	☑	
11.	No hot spots on BESS container surface	☑	*Do **not open** the door if a higher temperature is detected*
12.	No smoke coming out of BESS fan	☑	*Call Fire Brigade if smoke is detected*

2) Upper Deck Tech. Rooms

#	Item	Check	Comments / Actions Reqired
13.	Walkways and access routes are clear and unobstructed	☑	
14.	No open edge, no risk of falling from height	☑	
15.	No risk of dropped objects	☑	
16.	No loose items	☑	
17.	Safety signages in place	☑	
18.	Container doors closed	☑	
19.	Cables and wires are organized	☑	
20.	Safety cabinets in place and not damaged	☑	
21.	No signs of chemical or oil spills	☑	
22.	Vertical ladders are secure and usable	☑	

✓ Final Verification

☒ All platform inspected and safe for access ☐ All platform inspected and NOT safe for access

Date: 08/10/2025

Signature Rosetti Marino Ref.

D. Ricci

Signature CrossWind Ref.

HSE Walkdown Checklist - Safe access to BLPH

1) Lower Deck OUTSIDE

#	Item	Check	Comments / Actions Reqired
1.	Walkways and access routes are clear and unobstructed	☑	
2.	No open edge, no risk of falling from height	☑	BUSS has to fix the side doors
3.	No risk of dropped objects	☑	
4.	No loose items	☑	1 bolt, 1 water bottle
5.	Safety signages in place	☑	1 arrow fell due to banner
6.	Container doors closed	☑	
7.	Cables and wires are organized	☑	
8.	Safety cabinets in place and not damaged	☑	
9.	No signs of chemical or oil spills	☑	
10.	Vertical ladders are secure and usable	☑	
11.	No hot spots on BESS container surface	☑	*Do **not open** the door if a higher temperature is detected*
12.	No smoke coming out of BESS fan	☑	*Call Fire Brigade if smoke is detected*

2) Upper Deck OUTSIDE

#	Item	Check	Comments / Actions Reqired
13.	Walkways and access routes are clear and unobstructed	☑	
14.	No open edge, no risk of falling from height	☑	
15.	No risk of dropped objects	☑	N. 2 support on APN, 2 bolts
16.	No loose items	☑	
17.	Safety signages in place	☑	
18.	Container doors closed	☑	
19.	Cables and wires are organized	☑	
20.	Safety cabinets in place and not damaged	☑	
21.	No signs of chemical or oil spills	☑	
22.	Vertical ladders are secure and usable	☑	

✓ Final Verification

☒ All platform inspected and safe for access ☐ All platform inspected and NOT safe for access

Date: 08/10/2025

Signature Rosetti Marino Ref.

D. RICCI PICCIONI

Signature CrossWind Ref.